

**2020 Consumer Confidence Report Data**  
BLOOMFIELD, VILLAGE OF, PWS ID: 26514697

### Water System Information

If you would like to know more about the information contained in this report, please contact Domenic Alexandroni at (262) 206-6916.

This report will not be mailed to customers but will be available upon request.

Opportunity for input on decisions affecting your water quality

Village Board meetings are held on the second Monday of every month at 6:00 pm.

### Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

### Source(s) of Water

| Source ID | Source      | Depth (in feet) | Status |
|-----------|-------------|-----------------|--------|
| 1         | Groundwater | 1270            | Active |
| 2         | Groundwater | 1250            | Active |

To obtain a summary of the source water assessment please contact, Domenic Alexandroni at (262) 206-6916.

### Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

### Definitions

| <b>Term</b>        | <b>Definition</b>  |
|--------------------|--|
| AL                 | Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.  |
| Level 1 Assessment | A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.  |
| Level 2 Assessment | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions. |
| MCL                | Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.   |
| MCLG               | Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.   |
| MFL                | million fibers per liter   |
| MRDL               | Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.   |
| MRDLG              | Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.                           |
| mrem/year          | millirems per year (a measure of radiation absorbed by the body)   |
| NTU                | Nephelometric Turbidity Units  |
| pCi/l              | picocuries per liter (a measure of radioactivity)  |
| ppm                | parts per million, or milligrams per liter (mg/l)  |
| ppb                | parts per billion, or micrograms per liter (ug/l)  |
| ppt                | parts per trillion, or nanograms per liter   |
| ppq                | parts per quadrillion, or picograms per liter  |
| TCR                | Total Coliform Rule  |
| TT                 | Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.   |

#### Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

#### Disinfection Byproducts

| <b>Contaminant (units)</b> | <b>Site</b> | <b>MCL</b> | <b>MCLG</b> | <b>Level Found</b> | <b>Range</b> | <b>Sample Date (if prior to 2020)</b> | <b>Violation</b> | <b>Typical Source of Contaminant</b>      |
|----------------------------|-------------|------------|-------------|--------------------|--------------|---------------------------------------|------------------|---|
| HAA5 (ppb)                 | D-6<br>445  | 60         | 60          | 3                  | 3            |                                       | No               | By-product of drinking water chlorination |
| TTHM (ppb)                 | D-6<br>445  | 80         | 0           | 8.0                | 8.0          |                                       | No               | By-product of drinking water chlorination |

#### Inorganic Contaminants

| Contaminant (units) | Site | MCL | MCLG | Level Found | Range           | Sample Date (if prior to 2020) | Violation | Typical Source of Contaminant  |
|---------------------|------|-----|------|-------------|-----------------|--------------------------------|-----------|--|
| BARIUM (ppm)        |      | 2   | 2    | 2.100       | 1.200 - 2.100   |                                | No        | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits   |
| FLUORIDE (ppm)      |      | 4   | 4    | 0.7         | 0.7 - 0.7       |                                | No        | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories                  |
| NICKEL (ppb)        |      | 100 |      | 0.5300      | 0.0000 - 0.5300 |                                | No        | Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products. |
| SODIUM (ppm)        |      | n/a | n/a  | 120.00      | 97.00 - 120.00  |                                | No        | n/a  |

| Contaminant (units) | Action Level | MCLG | 90th Percentile Level Found | # of Results | Sample Date (if prior to 2020) | Violation | Typical Source of Contaminant  |
|---------------------|--------------|------|-----------------------------|--------------|--------------------------------|-----------|--|
| COPPER (ppm)        | AL=1.3       | 1.3  |                             |              |                                | No        | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives |
| LEAD (ppb)          | AL=15        | 0    |                             |              |                                | No        | Corrosion of household plumbing systems; Erosion of natural deposits                                   |

#### Radioactive Contaminants

| Contaminant (units)                  | Site | MCL | MCLG | Level Found | Range | Sample Date (if prior to 2020) | Violation | Typical Source of Contaminant  |
|--------------------------------------|------|-----|------|-------------|-------|--------------------------------|-----------|--|
| GROSS BETA PARTICLE ACTIVITY (pCi/l) |      | n/a | n/a  | 3.5         | 3.5   | 1/27/2016                      | No        | Decay of natural and man-made deposits. MCL units are in millirem/year. Calculation for compliance with MCL is not possible unless level found is greater than 50 pCi/l. |

| Contaminant (units)              | Site | MCL | MCLG | Level Found | Range     | Sample Date (if prior to 2020) | Violation | Typical Source of Contaminant |
|----------------------------------|------|-----|------|-------------|-----------|--------------------------------|-----------|-------------------------------|
| GROSS ALPHA, EXCL. R & U (pCi/l) |      | 15  | 0    | 7.6         | 5.8 - 9.3 |                                | No        | Erosion of natural deposits   |
| RADIUM, (226 + 228) (pCi/l)      |      | 5   | 0    | 5.5         | 1.7 - 5.5 |                                | No        | Erosion of natural deposits   |
| GROSS ALPHA, INCL. R & U (n/a)   |      | n/a | n/a  | 7.7         | 5.9 - 9.3 |                                | No        | Erosion of natural deposits   |
| COMBINED URANIUM (ug/l)          |      | 30  | 0    | 0.1         | 0.0 - 0.1 |                                | No        | Erosion of natural deposits   |

#### Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Bloomfield, Village Of is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

#### Other Compliance

#### Monitoring Violations

| Description                            | Contaminant Group            | Sample Location     | Compliance Period Beginning | Compliance Period Ending |
|--|------------------------------|---------------------|-----------------------------|--------------------------|
| PBCU M/R Tap Follow/Routine            | Lead and Copper              | Distribution System | 7/1/2020                    | 10/31/2020               |
| Chem M/R - Reg - No Regular samples    | Radioactive Contaminants     | 1                   | 10/1/2020                   | 12/31/2020               |
| Fail to collect Routine Samples - RTCR | Microbiological Contaminants | Distribution System | 12/1/2020                   | 12/31/2020               |

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted in the above table, we did not complete all monitoring or testing for the contaminant(s) noted, and therefore cannot be sure of the quality of your drinking water during that time.

#### Actions Taken

The utility was unable to collect lead and copper samples due to the DNR not approving our previously approved sample sites. The utility has been working with the DNR to get approval. A quarterly radioactivity sample was collected and shipped to the lab for testing. The sample was damaged in shipping. Samples will be collected at the beginning of the quarter as to allow enough time to resample. Bacteriological samples collected prior to and immediately after the missed sample met water quality standards. A monthly sample reminder has been implemented.

#### Uncorrected Significant Deficiencies

| <b>Deficiency Description and Progress to Date</b>            | <b>Date System Notified</b> | <b>Scheduled Correction Date</b> |
|---|-----------------------------|----------------------------------|
| Chemical storage and handling procedures are not appropriate. | 12/3/2020                   | 1/15/2021                        |

**Actions Taken**

Chemical vent tubing did not have a downward facing elbow, therefore being considered inappropriate. A 90-degree elbow was attached to the chemical vent tubing to meet the DNR regulations.