

GOVERNMENT OF MAHARASHTRA

Tel No. 2667 7555
Fax No. 2666 0287

Directorate of Maharashtra Fire Service
Maharashtra Fire Service Academy, Vidyanagri,
Hans Bhugra Marg, Santacruz (East), Mumbai - 400 098

Submitted please.

No. MFS/
Date :- 19th Sept 2020

Sub: Scrutiny Report of Proposed construction of Educational Building of Mr. Nivrutti R. Gite, M/s Jyotirmay Bhahuuddeshiya Santha's on plot bearing G. No. 33(pt), At Rasalpur, Tal Niphad & Dist Nashik.

Ref : Online Application of M/s Jayesh Infrastech Pvt. Ltd., Architects Vide No. NAS/01/02/2020/1089, Dated 01/02/2020.

With reference to the above M/s Jayesh Infrastech Pvt. Ltd., on behalf of Mr. Nivrutti R. Gite, M/s Jyotirmay Bhahuuddeshiya Santha's had submitted an application for grant of "Provisional No-Objection Certificate" from this office for construction of Educational Building at the above mentioned address.

The Plot area is 13800.00 and the built up area is 2489.61 Sq. Mtrs. The detail of the proposed Construction is as under. The area wise details of the proposed buildings are under.

Sr. No	Name of Building/Floor	Built up area in mtrs
1.	Ground Floor	829.87
2.	First Floor	829.87
3.	Second Floor	829.87
	Total	2489.61
	Height in Mtrs	12.15

Observation & Remarks:

This is proposal for the construction of Educational Building comprising of Ground + Two upper Floor with the height 12.15 mtrs from general ground to terrace floor. The building is provided with TWO open type staircase of width 2.00 mtrs leading from Ground to terrace floor. The architect has stated that the travel distance and open spaces are maintained as per the norms. The site abuts state highway and proposed 12 mtrs wide road and same shall be verified and approved by CO & Town Planning Dept. of concern Mun. Council if it is as per the norms and if min 12 mtrs wide approach road is not provided then this NOC shall be treated as cancelled.

As per Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Section 25-Annexure-Part III, party has paid Fire Protection Fund Fees amounting to Rs. 35,000/- (Rs. Thirty Five Thousand Only) vide UTR. No. KKBKH20258611777 dated 30/08/2020 as certified by the then Architect vide his letter.

A draft of "Provisional No-Objection Certificate" is placed below for favour of your information & approval, please. If approved we may issue a "Provisional No-Objection Certificate" to said College.

Submitted for favour of approval, please.


Umesh
Gopalrao
Palande

Digitally signed by Umesh Gopalrao Palande
DN: cn=U, o=Municipal Corporation of Greater Mumbai, ou=Mumbai Fire Brigade, postalCode=400008, st=MAHARASHTRA, serialNumber=1cd5d100cdee3ebf14af37c475df6ebcb4dd0cb1f3494dc62793095de8ac6047, cn=Umesh Gopalrao Palande
Date: 2020.09.19 17:07:27 +05'30'

Nominated Officer

Director: PRABHAT
SURAJLAL
RAHANGDALE

Digitally signed by PRABHAT SURAJLAL RAHANGDALE
Date: 2020.09.21 08:37:43 +05'30'



RATHI ENGINEERS & FIRE PROTECTION

Everything in Fire Safety & Equipment's
Shop No-01 Anand Apartment Behind Ambad Weight Bridge
Ambad Nashik-422310.
Mob.No.9890244993,8830080227. Mail ID.rathienginnerfire4455@gmail.com

Date-29-06-2024

CERTIFICATE

This is to certify that **SHRIMAHIMAN INTERNATIONAL SCHOOL**. Kothure Sinner Road
Opposite BSNL Office At Post Niphad, Taluka Niphad, District Nashik. the Under Noted Fire
Extinguisher Have Been Installed by Us and Are Warranted for Period of One Year
from The Date of Installation. As per.IS: - **2190: 2010**.


Sr No	DESCRIPTION	IS.NO	UOM	QTY.
01.	ABC FIRE EXTINGUISHER CAP.06 Kg.	- 2190: 2010	Nos	06
TOTAL: -			Nos	06

I/We Further Certify That These Installation in the Above-Mentioned Premises is
Maintained in Good Condition. As Required Under the Fire Prevention and Safety
Measures the Details of The Inspection Refilling Carried Out by Us Are Mentioned in
The Report Appended Herewith. We Undertake Repair, Rectification and Servicing
During the Period Of 1 Year from Date of Installing.

Refilling Dated: -29/06/2024

Due Date: -28/06/2025

For, Rathi Engineers and Fire Protection


NASHIK
Authorized Signatory.