

SPEC'S Pg. 1 of 2



A PLAYCORE Company

STANDARD SERIES – ALUMINUM ANGLE FRAME (4 ROW)

ITEM: 4 row x 27' portable bleacher having a seating capacity of 63 net seats, GT Grandstands Model No. GS-0427ADC-A

MANUFACTURER: GT Grandstands, Inc., 2810 Sydney Road, Plant City, FL 33566, Ph (866) 550-5511, Fax (813) 305-1419

DESIGN: The bleachers shall be designed to support, in addition to their own weight, a uniformly distributed live load of not less than 100 psf of gross horizontal projection of the bleachers. All seat and foot plank members shall be designed to accommodate 200 plf across a 6' span with a maximum deflection of 9/16". The bleachers shall be designed to resist, with or without a live load, a horizontal wind load of 30 psf of gross vertical projection. In addition to the live load, the bleachers shall be designed to resist the following sway forces: (1) 24 plf of seat plank in a direction parallel to the length of the seat, and (2) 10 plf of seat plank in a direction perpendicular to the length of the seat. Under these loads, stresses in aluminum members and connections shall not exceed those specified for Building Type Structures by the Aluminum Association.

CONSTRUCTION: The understructure, including crossbracing, shall be of a welded, aluminum angle (6061-T6 alloy, mill finish) construction. The understructure of each unit shall consist of frames spaced at 6' centers joined by crossbracing at adequate points to comply with the design loads.

DIMENSIONS: The rise per row shall be 8", seat height 17", and tread depth per row of 24". Overall depth of unit is 9'-5". Clear width of unit is 22'. Top row seat height is 4'-0"

GUARDRAILS: Guardrail system shall be at all sides of bleacher. Railing shall be 1 5/8" anodized aluminum tube with end caps at ends of straight runs and elbows at corners. All railing shall be secured to rail posts by galvanized fasteners. Guardrailing shall include 2", 9 gauge galvanized chain link fencing fastened in place with galvanized fittings and aluminum ties. Top of railing shall be 42" above the center of any adjacent seat. The guardrail system shall have no opening larger than 4" at any location more than 30" above grade including the triangular region underneath the seat formed by the tread and rise. The guardrail system shall be capable of sustaining a horizontal load of 50 plf and a vertical load of 100 plf. In addition the guardrail system shall be designed for a 200 lb concentrated load applied to the top rail in any direction.



SEAT PLANKS: Seat planks shall be 2"x10" nominal, extruded 6063-T6 aluminum alloy with a clear anodized finish and end cap attached with tek screws.

www.seatingspecialists.com
(817) 312-9131 • Fax (817) 426-4844
P.O. Box 1593
Burleson, TX 76097
Email: traclight444@aol.com