

# *Air Driven Odor Control Systems*

## **HLDA500** Pump Maintenance



1.

Prepare drum suction end LMI Pump hose per photo and place in a drum.



2.

Set and prime pump by turning black knob to between 12 o'clock and 10 o'clock.



3..

Secure the pump to the provided plate and connect tubing to the system. a visual access portal is provided above the injection lance for inspection.



4.

Connect pump to electrical cord to GFCI on the system control panel. Prime and set the pump to 30% speed and 30% stroke for 1/2 gallon a day.