



Technical requirement:

- 1.Face to face dimension meets the customer's requirement;
- 2.Testing conforms to FM;
- 3.Working pressure:175 PSI;
- 4.The groove connection conforms to AWWAC606;

9	Electric Signal Gear Box	
8	Key	1045
7	Circlip	65Mn
6	Gasket	SS304
5	O-Ring	EPDM
4	Lower Shaft	SS630
3	Disc	65-45-12+EPDM
2	Upper Shaft	SS630
1	Body	ASTM A536 65-45-12
Item	Name	Material

DN	L	O	C	A	B	H1	H2	L1
50	114	60.3	57.15	16	8	50	50	66.5
65	114	73	69.1	16	8	55.5	55.5	66.5

Manufacture/Supplier:				SHOP DRAWING				FIG NO. GD-3000					
SENTRY SPRINKLERS												TITLE: Fire Butterfly Valve (Groove Connection) 2"-2.5" (DN50-DN65)	
				REV.	BY	APP.	Description	Date	Projection	ALL DIM'S IN: mm DO NOT SCALE FROM DRAWING		DRAWING NO. :	