


| | | | | | |
|-------------|---|----|----|----|----|
| Consequence | 5 | 10 | 15 | 20 | 25 |
| | 4 | 8 | 12 | 16 | 20 |
| | 3 | 6 | 9 | 12 | 15 |
| | 2 | 4 | 6 | 8 | 10 |
| | 1 | 2 | 3 | 4 | 5 |
| Likelihood | | | | | |

- Unacceptable – Stop activity
- Adequate – Monitor for continual compliance
- Acceptable – No further action / monitor

| | |
|------------------|-------------------------------------------------------------------------------------|
| Risk Assessment: | 005 Asbestos |
| Assessors Name: | Rob Shaw |
| Signature: |  |
| Date: | November 2023 |
| Review: | November 2024 |

Location: 6 New Road – PE14-9AB

| | | | | | |
|-------------|-------------------|--------------|-------------------|------------|------------------|
| Likelihood | 1 = Very unlikely | 2 = Unlikely | 3 = Fairly likely | 4 = Likely | 5 = Very likely |
| Consequence | 1 = Insignificant | 2 = Minor | 3 = Moderate | 4 = Major | 5 = Catastrophic |

| Hazard | Who can be harmed & how | Risk Rating | | | Control measures in place | Residual Risk | | |
|----------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|-------------|---|----|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|---|----|
| | | L | C | R | | L | C | R |
| Disturbing Asbestos – Breathing in fibres- may lead to lung cancer, asbestosis, fibrosis or Mesothelioma | Village Hall employees, visitors, hirers and contractors, delivery / collection drivers, trespassers and intruders. | 5 | 5 | 25 | Asbestos Awareness training to identify and report to management and to make arrangements for qualified and licensed asbestos removal to make safe if required. DO NOT disturb any possible Asbestos found. Building will have an Asbestos record / report prior to a build date of 2000. If in doubt do not proceed. | 5 | 5 | 25 |