

**Mission:**

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



**Ron DeSantis**  
Governor

**Joseph A. Ladapo, MD, PhD**  
State Surgeon General

**Vision:** To be the Healthiest State in the Nation

## Greater Pine Island Water Association, PWS #: 5360322

### 2022 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports.
Disinfectant Residuals Report	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. (if required)
Nitrate and Nitrite	2022	Sample at each POE* every year.
Primary Inorganics	2023	Sample at each POE every 3 years.
Secondaries	2023	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha</i> )	2026	Sample at each POE every 6 years.
Radiologicals ( <i>Radium 226/228</i> )	2023	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2023	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2023	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Annual	System is on <u>reduced</u> (annual) testing at 2 sites for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with Stage 2 D/DBP Monitoring Plan.
Asbestos	2029	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2022	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2022 & August 10, 2022	The CCR template can be obtained at: <a href="http://www.frwa.net/CCR/CCR%20Main%20Page.htm">http://www.frwa.net/CCR/CCR%20Main%20Page.htm</a>
Finish Water Tank Inspections	On Site 2024 Central 2024 Scallop 2024	All tank inspections must be done every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2022 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact our office as soon as possible. This chart shall not relieve any person from any requirement of Florida law.

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/22 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
  
- **Test results must be submitted to DOH-Lee within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**

Rosa Esparza    01/31/2022  
**Prepared By**    **Date**

Florida Department of Health Lee County  
Environmental Engineering  
(239) 274-2217