



NOTES:

1. CONCRETE STRENGTH = MIN. 4500 PSI
2. STRUCTURAL FIBER REINFORCEMENT
3. "POLYLOK" PIPE SEALS CAST IN TANK
4. INLET IS 2" HIGHER THAN THE OUTLET



CTJAMISON.COM
PH: 540-483-5944

Distribution Boxes

Date
Feb 2016

Scale
Not To Scale