



CBPE Inc
Fire Sprinkler
Testing Service

14489 s. Majestic Oaks Lane
 Herriman, UT 84096
 801-886-3473
 Craig@Cbluepe.com
 CBPEtesting.com

FIRE SPRINKLERS HAVE BEEN FIELD TESTED IN
 ACCORDANCE WITH APPLICABLE NFPA #25.
 DATE OF TEST: 12/06/22
 BLDG NAME: Grey Hawk Condos- 1s1794
 BLDG ADDRESS: 675 Deer Valley Drive
 Park City, UT

Submitted by: **Delta Fire Systems**
PO#4701-150086

CBPE # 2001-58
 UT Cert# S11047

NEXT TEST SHALL OCCUR 10 YRS FROM PREVIOUS DATE

2032

Testing by: Craig Blue PE.

SAMPLES PASSED TESTING - ATTACH TO SYSTEM RISER.

BRAND	MODEL	SIN#	YR	K-FACTOR	TEMP F	TEMP C	SOLDER MECH GLASS	SR/QR	DRY/WET SYSTEM	LOCATION OF SAMPLE	NPT	SYSTEM ZONE REF.	UPR/PEND/ SIDE/DRY	
1	Viking	M4	#24s3	1996	80mm (5.6)	155	68	3mm GB	QR	Wet	Unit 11	1/2" (15mm)	Wet	Pendent
2	Viking	M4	#24s3	1996	80mm (5.6)	155	68	3mm GB	QR	Wet	Unit 26	1/2" (15mm)	Wet	Pendent
3	Viking	M4	#24s3	1996	80mm (5.6)	155	68	3mm GB	QR	Wet	Unit 25	1/2" (15mm)	Wet	Pendent
4	Viking	M4	#24s3	1996	80mm (5.6)	155	68	3mm GB	QR	Wet	Unit 17	1/2" (15mm)	Wet	Pendent
5	Viking	M4	#24s3	1996	80mm (5.6)	155	68	3mm GB	QR	Wet	Unit 20	1/2" (15mm)	Wet	Pendent
6	Viking	M-ECOH	589A	1998	161 mm(11.2)	155	68	3mm GB	QR	Wet	x	3/4" (16 mm)	Wet	Upright
7	Viking	M-ECOH	589A	1998	161 mm(11.2)	155	68	3mm GB	QR	Wet	x	3/4" (16 mm)	Wet	Upright
8	Viking	M-ECOH	589A	1998	161 mm(11.2)	155	68	3mm GB	QR	Wet	x	3/4" (16 mm)	Wet	Upright
9	Viking	M-ECOH	589A	1998	161 mm(11.2)	155	68	3mm GB	QR	Wet	x	3/4" (16 mm)	Wet	Upright