

## DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

TO,

Jeevan Jyoti Public School  
V.P.O Bhaini Mian Khan, Gurdaspur

No.: DWTLGSP/2324/00351 Dated : 13/02/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. jjps/gen/2024 Dated: 09/02/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 09/02/2024 It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A : Test Report



Authorized Signatory  
For, District Water Testing Laboratory  
Gurdaspur

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

## TEST REPORT

Name & Address of Customer : <b>Jeevan Jyoti Public School</b> <b>V.P.O Bhaini Mian Khan, Gurdaspur</b>	Customer Reference No.	No : jjps/gen/2024 Dated : 09/02/2024
	Sample Submitted by	Principal
	Date of Sample Receipt	09/02/2024
	Analysis Starting Date	09/02/2024
	Analysis completion Date	12/02/2024

Discipline : <b>Chemical Testing</b>	Group: <b>Water</b>	
ULR No.:	Sample Type :	Water
Test Report No.: <b>DWTLGSP/2324/00351</b>	Date of Issue :	13/02/2024
Registration no.: <b>DWTLGSP/REG2324/00624</b>	Condition of Sample :	Unsealed
Collection Point: <b>Private Submersible</b>	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source: <b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>Jeevan Jyoti Public School / 325 ft</b>
Village : <b>Bhaini Mian Khan</b>	Habitation :	<b>Bhaini Mian Khan</b>
Block: <b>Kahnuwan</b>	District :	<b>Gurdaspur</b>
Latitude : <b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.4	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	7	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	290	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	128	200	600	mg/l	IS 3025 (Part 23-2023) indicator Method
8	Hardness	168	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	25.65	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	25.27	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

11	Chloride	12	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

Note: Detection Limit(Turbidity:0.5, )

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Gurdaspur

----- End of the Test Report -----