

TEST BORING LOG



Eversource Energy
South Fork Wind Farm
East Hampton, New York

EXPLORATION NO.: **SB-20A**
SHEET: 1 of 1
PROJECT NO: 41.0162804.02
REVIEWED BY: Rick Carlone

Logged By: Jessie Batalon
Drilling Co.: ADT
Foreman: Chris Iodice

Type of Rig: N/A
Rig Model: N/A
Drilling Method:
Hand Auger

Boring Location: See Plan
Ground Surface Elev. (ft.): 30
Final Boring Depth (ft.): 5
Date Start - Finish: 12/23/2020 - 12/23/2020

H. Datum:
V. Datum: NAVD88

Hammer Type: N/A
Hammer Weight (lb.): N/A
Hammer Fall (in.): N/A
Auger or Casing O.D./I.D Dia (in.): N/A

Sampler Type: Hand Auger
Sampler O.D. (in.): 4"
Sampler Length (in.): N/A
Rock Core Size: N/A

Groundwater Depth (ft.)

Date	Time	Stab. Time	Water	Casing
Not Measured				

Depth (ft)	Casing Blows (Core Rate)	Sample					SPT Value	Sample Description Modified Burmister	Remark	Field Test Data	Stratum Description Elev. (ft.)		Equipment Installed
		No.	Depth (ft.)	Pen. (in)	Rec. (in)	Blows (RQD)					Depth (ft.)	Elev. (ft.)	
5		S-1	0.0					S-1: Dark brown SILT, some fine Sand, trace Organics (leaves, roots), moist	1		0.5	TOPSOIL 29.5	No Equipment Installed
		S-2	0.5					S-2: Brown fine SAND, trace fine Gravel, trace Silt, moist	2	0.1		SAND	
								End of exploration at 5 feet.	3		5	25.0	

