Standby Power Inc. Generator Preventative Maintenance - MINOR P. M.

Charge to				Job #		
Street				Location		
City				See Mr.		
				Directions		
1) C	Check engine of	l level, add oil if necessary.				
2)	Check coolant l	evel, add coolant if necessary.				
3) Inspect cooling system, check all hoses, belts and fans						
4) Check heater operation where applicable.						
5) Check unit for leaks.						
6) (6) Check air cleaner.					
7) Check gaseous fuel system, carburetor, regulator, solenoid, manual shut-off, piping supply.						
8) C	8) Check diesel fuel system, day tank, lift pump, supply and return lines.					
9) Check battery, Perform resistive load test, check voltage, specific gravity, service if necessary.						
10) Inspect generator control and rotating section for dirt and foreign materials.						
11)	11) Run generator no load.					
12) Check output voltage and frequency meter, safety and fault indicator lights.						
13) Check operation of all louver and damper motors for cooling air intake and exhaust.						
14) Check exhaust system for leaks, drain condensation trap.						
15) Inspect unit for unusual sound or vibration.						
16) Check output voltage and frequency at emergency terminals in transfer switch.						
17)	Check Battery	charger.				
18) Visual inspection of all components.						
19)	Record hour m	eter reading where applicable.	Hrs			
20)	Inspect area su	rrounding generator for foreign mater	ials tha	t could pose a safe	ety or fire hazard.	
Qty.	Part Number	Description	Qty.	Part Number	Description	

X-Denotes all checked & OK.

C- Denotes see noted comment.