

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 21

Dated: 3-4-24

It is certified that an inspection team headed byMiss Divya Chohan.....JEN,PHED Bijainagar(Name of Officers with designation) from PHED Bijainagr PHED Inspected the Pragma International School, Ward No. 02, Bijainagar-305624 (Name & Address of the school) on 03 April 2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 1899 dated 11-12-2023 Of PHED LAB AJMER (PHED Lab) certified that the Pragma International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 02 April 2025

Signature with Seal


PHED

Name

Shri. Dev Anand

राज्यिक अभियन्ता
जन. स्व. अमि विभाग
राजस्थान-विक्रमनगर

Designation

ABN PHED Bijainagar

Name & Address of the Office / Department:.....


PHED Bijainagar

To
Pragma International School
Ward No. 02, Pragma Road,
Bijainagar-305624
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Principal
Pragma International School
Bijainagar (Ajmer)


Manager
Pragma International School


शक्ति
श्री प्राज्ञ जैन स्मारक समिति
विक्रमनगर (अजमेर) राज

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY, AJMER (Raj)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No.Lab/Tech./ 2023-24/ 1838

Date: 11.12.2023

Sample was not Collected
by Laboratory

To,
Principal
Pragya International School
Bijainagar (Ajmer)

District: AJMER
Tehsil:- BIJAINAGAR

Not for Legal Purpose

Reference : Your Letter No.- PIS/23-24/62 Date 07.12.2023
 Sample Collected by :- Sh Hemraj Prajapat


Date of Receipt :- 07.12.2023

Lab Sample No.		IS10500:2012		P-29
Source :		Desirable Limit as per IS10500:2012	Permissible Limit in absence of alternate source	Tap
Source Location:				Treated by Aquaguard Pragya International School
Town / Village				Bijainagar
Date of Collection→				07.12.2023
Date of Examination→				07.12.2023
Test Parameter↓				Results↓
1	pH Value			6.5 - 8.5
2	Turbidity (NTU) Max	1	5	Nil
3	Colour (Hazen Units), Max	5	15	Nil
4	Odour	Agreable		Agreable
5	Total Alkalinity (as CaCO ₃) mg/l, Max	200	600	110
6	Total Hardness (as CaCO ₃) mg/l, Max	200	600	130
7	Chlorides as Cl ⁻ mg/l, Max	250	1000	60
8	Fluorides as F ⁻ mg/l, Max	1.0	1.5	0.28
9	Nitrate as NO ₃ ⁻ mg/l, Max	45	No Relaxation	2
10	Total Dissolved Solids(T.D.S.) mg/l, Max	500	2000	335
11	Residual Chlorine	0.2	1.0	Nil
		Applicable only when water is Chlorinated		

Note: 1. The sample was not collected by this laboratory.
 2. This Report is not for legal Purpose.


Manager
 Pragya International School


Principal
 Pragya International School
 Bijainagar (Ajmer)


 (Dr. Archana Mathur)
Superintending Chemist
 P.H.E.D.Regional Lab.,Ajmer


सचिव
 श्री प्राज्ञ जैन स्मारक समिति
 -जयनगर (अजमेर) राज

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, REGIONAL LABORATORY, AJMER
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No. Lab/Tech(Bact)/ १११

Sample was not Collected
by Laboratory

Date 11.12.2023

To,

Principal
Pragya International School
Bijainagar (Ajmer)

~~Not for Legal Purpose~~

District: AJMER
Tehsil:- Bijainagar

Reference : Your Letter No.- PIS/23-24/62 , Date 07.12.2023

Sample Collected by :- Sh Hemraj Prajapath


Sr. No.	Lab Sample No.	Date & Time of Collection	Date of Examination	City / Village	Source & Location	Residual Chlorine (mg/L)	Total Coliform Organism MPN/100 ml.
1	B-14	07.12.2023 10.00 am	07.12.2023	Bijainagar	Tap water (Treated by Aquaguard) , Pragya International School	Nil	Nil


Remarks

Satisfactory: L.S. No.- B-14
Unsatisfactory: Nil

11/12/2023
(Dr. Archana Mathur)
Superintending Chemist
P.H.E.D. Lab.,Ajmer


Manager
Pragya International School


Principal
Pragya International School
Bijainagar (Ajmer)


सचिव
श्री प्राज्ञ जैन स्मारक समिति
बिजयनगर (अजमेर) राज