



Hocker Incorporated
 13402 Weiman Road Houston, TX 77041
 713-464-5829 Fax 713-464-3192

Customer PO #:	86476
Certification #:	23-1333

**ASTM E317-16 Performance Evaluation
 Ultrasonic Flaw Detector**

Calibration Date:	10/5/2023
-------------------	-----------

F-UTFL Rev-0

Meets ASTM E317-16 Minimum Requirements?	YES
--	-----

Due Date:	10/5/2024
-----------	-----------

Company:	P&B Testing Inc.		Equipment Model & Serial #	Sonatest 350M sn-I008767		Equipment Condition As Found:	
Address:	6645 W. Tidwell						
City:	Houston						
State:	Texas	Contact:	Buck Sneider				
Zip:	77092	Phone:	713-290-8490		Temp:	72°F	
Country:	USA	Email:	ga@pbtesting.com		Hum. %:	51%	

Performance Evaluation Equipment:	Serial:	NIST:	Cert. Blocks C to G:	Serial:	NIST:
Calib. Block A	ASTM-E317 Block	SN 03-8399	03-19698-A	ASTM E127 1-0300	SN 15-8035
Calib. Block B	ASTM Type RA	SN 04-5671	04-25714-A	ASTM E127 2-0300	SN 15-8036
Transducer "A"	FCHR-5050 Hi Res	SN 931/37	n/a	ASTM E127 3-0300	SN 15-8037
Transducer "B"	PSLM-5050 5mhz 1/2"	SN 504/03	n/a	ASTM E127 4-0300	SN 15-8038
Transducer "C"	PSLM-5050 5mhz 1/2"	SN 424/20	n/a	ASTM E127 5-0300	SN 15-8039

Calibrated Attenuator	S/N: SO383925	NIST #:	1821-1022/1104681/9000-1439,1230,1336
-----------------------	---------------	---------	---------------------------------------


Horizontal Limit Linearity		Vertical Limit Linearity	
Horiz. Accuracy Limit + or -	2.0%	Verticle Accuracy Limit + or -	2.0%
Meets Accuracy Required?	Yes	Meets Accuracy Required?	Yes
Horiz. Accuracy Deviation	0.0%	Vert. Accuracy Deviation	-2.0%
Horiz. Screen Width used?	10"	Equipment Overall Pass/ Fail Result:	Pass

% Horiz. Screen Width				% Vertical Screen Height					
Echo #	Actual %	Ideal	Deviation	Ideal %	Actual %	Ideal%	Actual%	Ideal%	Actual%
				+1db steps		-2db steps		-4db Steps	
1	0.0%	0.0%	0.0%						
2	10.0%	10.0%	0.0%	50.0%	50.0%	50.0%	50.0%	16.0%	16.0%
3	20.0%	20.0%	0.0%	56.0%	55.0%	40.0%	40.0%	10.0%	10.0%
4	30.0%	30.0%	0.0%	63.0%	62.0%	31.0%	31.0%	6.0%	6.0%
5	40.0%	40.0%	0.0%	71.0%	69.0%	25.0%	25.0%	5.0%	4.0%
6	50.0%	50.0%	0.0%	79.0%	78.0%	20.0%	20.0%	3.0%	2.0%
7	60.0%	60.0%	0.0%	89.0%	88.0%	16.0%	16.0%	2.0%	1.0%
8	70.0%	70.0%	0.0%	100.0%	98.0%				
9	80.0%	80.0%	0.0%	Maximum Vertical Deviation				-2.0%	
10	90.0%	90.0%	0.0%	Sensitivity & Noise					
11	100.0%	100.0%	0.0%						


Maximum Horizontal Deviation	0.0%	Test Block Number	Sig. Ampl.	Break Pt.	Noise Lvl.	Hole Size
Accuracy Of Calibrated Gain Controls		ASTM E127 1-0300	60.0%	8.0%	1.0%	1/64
Ideal	Actual	ASTM E127 2-0300	60.0%	8.0%	1.0%	1/32
1	1	ASTM E127 3-0300	60.0%	9.0%	1.0%	3/64
2	2	ASTM E127 4-0300	60.0%	10.0%	1.0%	1/16
4	4	ASTM E127 5-0300	60.0%	10.0%	1.0%	5/64
6	6		Gain Control Deviation DB		0	

Near Surface Resolution at 80%			Far Surface Resolution at 80%			Max Noise Level (Sensitivity & Noise Test)	1.0%
Depth	Break Pt.	Noise %	Depth	Break Pt.	Noise %		
0.7"	16.0%	1.0%	.01"	15.0%	1.0%	Max Noise Level (Resolution Test)	1.0%
0.5"	12.0%	1.0%	.02"	17.0%	1.0%		
0.3"	11.0%	1.0%	.03"	18.0%	1.0%		

Horizontal Linearity As Received!



Vertical Linearity As Received!



Notes:

This performance evaluation was done in accordance with ASTM-E317-16 and Hocker Incorporated procedure CP-UTFL Rev 0. Test equipment and calibration blocks used to perform this evaluation are traceable to the National Institute of Standards and Technology. NIST numbers listed in this document and supporting documentation is on file. This performance evaluation is made in conformance with ANSI/NCSL 2540.3-2006 and/or ISO 10012, and with 10CFR21.

Technician Signature:

F-UTFL Rev-0 05/01/2018

Technician Performing Evaluation: Roger Kimmons

Date: 10/5/2023

Approval Signature:

Approved By: Derrick Schumann

An ISO 9001:2015 Registered Company