



JOMON  
PERSADA  
NUSANTARA

# FIRE SUPPRESSION SYSTEM CATALOG





Description	IFES Indicating Alarm Panel Kit
Part Number	AAEL0869
Features	Test button
	Full System Test
	Fault Code Indication
	Beep Code Indication
	Mute Function
	Programmable
	Fault Storage
	Isolate Function
Reset Function	



Description	IFES Control Indicating Alarm Panel Kit
Part Number	BBEF1163
Features	Test button
	Full System Test
	Fault Code Indication
	Beep Code Indication
	Mute Function
	Programmable
	Fault Storage
	Isolate Function
	Reset Function
Actuator Switcth	

# MANUAL ACTUATOR



Description	Manual Actuator Valve Assembly Mounting Housin
Part Number	AAEN0225



Description	Manual Actuator Electric MCP
Part Number	BBEF1117

# CYLINDER TANK



Description	28 LITRE Cylinder, - 3/4" LOP Valve, KIT, Flexible
Part Number	AAEN0330
Test Pressure	3.0 Mpa Hydrostatically tested at manufactured
Max Safe Pressure	2.0 Mpa
Normal Charge Pressure	1.37 Mpa A directed in this manual
Painting	Powder Coated Signal Red AS-5062
Fittings	Main Neck Ring 1 1/4 BSP Male – Filler Port 1 1/4 BSP Female



Description	45 Litre Cylinder, -3/4" LOP Valve, KIT, Flexible
Part Number	AAEN0344
Test Pressure	3.0 Mpa Hydrostatically tested at manufactured
Max Safe Pressure	2.0 Mpa
Normal Charge Pressure	1.37 Mpa A directed in this manual
Painting	Powder Coated Signal Red AS-5062
Fittings	Main Neck Ring 1 1/4 BSP Male – Filler Port 1 1/4 BSP Female



Description	120 Litre Cylinder, - 3/4" LOP Valve, KIT, Flexible
Part Number	AAEN0365
Test Pressure	3.0 Mpa Hydrostatically tested at manufactured
Max Safe Pressure	2.0 Mpa
Normal Charge Pressure	1.37 Mpa A directed in this manual
Painting	Powder Coated Signal Red AS-5062
Fittings	Main Neck Ring 1 1/4 BSP Male – Filler Port 1 1/4 BSP Female



Description	32 Litre Cylinder, - 3/4" LOP Valve, KIT, Flexible
Part Number	AAEN0666
Test Pressure	3.0 Mpa Hydrostatically tested at manufactured
Max Safe Pressure	2.0 Mpa
Normal Charge Pressure	1.37 Mpa A directed in this manual
Painting	Powder Coated Signal Red AS-5062
Fittings	Main Neck Ring 1 1/4 BSP Male – Filler Port 1 1/4 BSP Female

# REPAIR KIT



Description	Valve LOP Service Kit
Part Number	AAEN0183
	AAEN0190
	AAEN0288
Type	3/4" LOP Fast Flow Valve
	One Moving Part (Pressure Differentiating Valve)
	Stainless Steel Body
	Brass Piston
	Safety Relief Vent
	Rebuild Kit Available



Description	Manifold 1/8" 3 Port- Installation Kit (Indpan)
Part Number	ACCH0022



Description	Fire Alarm Pressure Switch 2 Bar Installation Kit
Part Number	BBEF0022



Description	Low Pressure Switch 9 Bar Installation Kit
Part Number	BBEF0260



<b>Description</b>	<b>Linear Heat Detection Cable Installation</b>
Part Number	BBEF1137



<b>Description</b>	<b>12V Selenoid Normally Closed Installation Kit</b>
Part Number	BBEF1124



<b>Description</b>	<b>Redundancy Sensor Install Kit Fullelectric System</b>
Part Number	BBEF1131



Description	Nozzle 60° Cap and Lanyard
Part Number	AEAA0022
Nozzle Type	60°
Optimum	870 mm
Minimum	500 mm
Maximum	1,200 mm



Description	Nozzle 100° Cap and Lanyard
Part Number	AEAA0029
Nozzle Type	100°
Optimum	300 mm
Minimum	200 mm
Maximum	600 mm



**OUR WEBSITE**



**Phone: +6221 2294 6465**

**Email: [sales@jomonindonesia.com](mailto:sales@jomonindonesia.com)**

**Address: Central Cakung Business Park Blok G2  
No. 1-2, Jl. Cakung Cilincing Raya KM. 3, Rorotan,  
Cilincing, Jakarta Utara, Indonesia - 14140**



**PT Jomon Persada Nusantara**



**@jomonindonesia**