

**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)**  
**ROOM NO. 209, VARUNALAYA PHASE-I**  
**KAROL BAGH, NEW DELHI – 110005**  
**# 23558264**

No./DJB/EE(RWH/GWC)/2019/ 868

DATED: 8/3/19

To,

Principal,  
Jai Hind Public School,  
Main Bawana Road,  
Pooth Khurd, Delhi-39


**Subject:-Regarding adequacy of rain water harvesting system at Jai Hind Public School, Main Bawana Road, Pooth Khurd, Delhi-39.**

Sir/Madam,

The above said unit has been inspected by Joint Inspection Team on 06.03.2019, constituted by Hon'ble NGT in O.A. No. 217/2016. It was found that One No. RWH pit is existing at site.

The existing RWH structure is adequate to harvest the roof top run-off for catchment area of above said unit. The RWH structure was found to be functional at the time of inspection.

You are advised to keep the existing RWH system neat & clean & maintain the same periodically. Rain Water conveyance system shall be duly kept connected to RWH pits and filter media shall be maintained and kept neat & clean, as per DJB norms and over flow shall always remain connected to municipal drain.

  
EE (RWH/GWC)  
EE (G W CELL)  
DELHI JAL BOARD  
VARUNALAYA BHAWAN,  
JHANDEWALLAN, N.D.-05