

DRINKING WATER NOTICE

Hamler Village Has Levels of TTHM above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM over the last four quarters was **0.105 mg/L at DS201** and **0.081 mg/L at DS202**. The standard for TTHM is **0.080 mg/L**.

What should I do?

- You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing trihalomethanes more than the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

What is being done?

The Village is currently working with Jones and Henry Engineers to create a new General plan investigating all available options to get the PWS back into Compliance. The current best strategy is to add a Granular Activated Carbon filtration to remove the contaminate prior to distribution.

Additional information may be obtained by contacting:

Contact Person: Ken Griffith

Phone Number: 419-274-7651

Mailing Address: PO Box 435 Hamler OH 43524

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: 12-28-2023

PWSID OH3500312 Facility ID DS1

Monitoring Period Fourth Quarter of 2023