

# TYPE EXAMINATION CERTIFICATE

## FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL 09-400-1002-088-02 Revision no.: 5  
Description of the product : Fire resistant central opening lift landing door  
Trademark : Crippa  
Type no. : CRP 04  
Name and address of the manufacturer : Çağın Asansör İmalat İnşaat Tarım Ürünleri ve Tarım Aletleri San. ve Tic. Ltd. Şti.  
Ayaş Yolu 26.km, Yenikent, Ankara, Turkey  
Name and address of the certificate holder : Çağın Asansör İmalat İnşaat Tarım Ürünleri ve Tarım Aletleri San. ve Tic. Ltd. Şti.  
Serhat Mah. Hasemek Sanayi Sitesi, 1465.Sokak (Eski 676.Sokak) No:17 Ostim, Yenimahalle, Ankara, Turkey  
Certificate issued on the following requirements : Lifts Directive 2014/33/EU section 4.2  
Certificate based on the following standard : EN 81-58:2022  
Test laboratory : FIRES, s.r.o.  
Date and number of the laboratory report : March 25, 2009, FIRES-FR-036-09-AUNE  
Date of type examination : December 2022  
Classification : 

The performance criteria of the EN 81-58 covered are:			
	E	EI	EW
Crippa, CRP 04 central opening	120	90	60

  
Additional document with this certificate : Report belonging to the type examination certificate no.: NL 09-400-1002-088-03 rev.5  
Additional remarks : This revision replaces certificate NL 09-400-1002-088-03 rev. 4 of 06-10-2017  
Conclusion : The lift landing door CRP 04 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2022, in particular for the classification indicated above.

Amsterdam

Date : 01-12-2022  
Valid until : 01-12-2027

  
ing A.J. van Ommen  
International Business  
Manager

  
Certification decision by  
W. Visser  
Certification Expert