

TYPE EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL 09-400-1002-088-03 Revision no.: 5
Description of the product : Fire resistant side opening telescopic lift landing door
Trademark : Crippa
Type no. : CRP 03
Name and address of the manufacturer : Çağın Asansör İmalat İnşaat Tarım Ürünleri ve Tarım Aletleri
San. ve Tic. Ltd. Şti.
Ayaş Yolu 26.km, Yenikent, Ankara, Turkey
Name and address of the certificate holder : Çağın Asansör İmalat İnşaat Tarım Ürünleri ve Tarım Aletleri
San. ve Tic. Ltd. Şti.
Serhat Mah. Hasemek Sanayi Sitesi, 1465.Sokak (Eski
676.Sokak) No:17 Ostim, Yenimahalle, Ankara, Turkey
Certificate issued on the following requirements : Lifts Directive 2014/33/EU Section 4.2
Certificate based on the following standard : EN 81-58:2022
Test laboratory : FIRES, s.r.o.
Date and number of the laboratory report : March 25, 2009, FIRES-FR-037-09-AUNE
Date of type examination : December 2022
Classification :

The performance criteria of the EN 81-58 covered are:			
	E	EI	EW
Crippa, CRP 03 side opening	120	120	60

Additional document with this certificate : Report belonging to the type examination certificate
no.: NL 09-400-1002-088-03 rev.5
Additional remarks : This revision replaces certificate
NL 09-400-1002-088-03 rev. 4 of 06-10-2017
Conclusion : The lift landing door CRP 03 meets the requirements of the Lift
Directive, Annex I section 4.2 and the EN 81-58:2022, in
particular for the classification indicated above.

Amsterdam

Date : 01-12-2022
Valid until : 01-12-2027


ing A.J. van Ommen
International Business
Manager


Certification decision by
W. Visser
Certification Expert