

RELEASES / DATES	
100% Construction Documents	DATE: 6/07/23
	DATE:
	DATE:
	DATE:
	DATE:
	DATE:

Mulberry Springs Winery
New Construction
4527 JM Turk Road
Flowery Branch, GA 30542
(HALL COUNTY)

PROJECT CONTACT:
MARK FAUL 678-472-6327

ISSUED FOR
CONSTRUCTION

DRAWN BY: BGB
REVIEWED BY: J. WREN




06/07/23

BASEMENT LEVEL
ELECTRICAL

EarthStation
Architecture & Design, Inc.
EarthStation Architecture & Design
105 Sycamore Place, Studio A-419
Decatur, GA 30030
Tel: 404.966.5963
email: jeff@earthstationarchitecture.com

DATE: 06/07/23 PROJECT NUMBER: ES: A2208
DRAWING NUMBER

E 2 0 3



1 BASEMENT LEVEL - ELECTRICAL

SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- PROVIDE GFCI PROTECTION FOR ALL DEVICES LOCATED WITHIN 6' OF A SINK. WHERE GFCI DEVICES ARE PROVIDED, THEY SHALL BE INSTALLED IN A READILY ACCESSIBLE LOCATION.
- REFER TO MECHANICAL EQUIPMENT CONNECTION SCHEDULE FOR CIRCUITING REQUIREMENTS OF ALL MECHANICAL EQUIPMENT.
- REFER TO EQUIPMENT CONNECTION SCHEDULE FOR CIRCUITING REQUIREMENTS OF ALL EQUIPMENT.
- REFER TO MECHANICAL DRAWINGS FOR EXACT LOCATIONS OF ALL MECHANICAL EQUIPMENT.
- VERIFY VOLTAGES OF ALL MECHANICAL EQUIPMENT WITH MECHANICAL SHOP DRAWINGS PRIOR TO ROUGH-IN.

KEY NOTES

- PROPOSED LOCATION OF SERVICE ENTRANCE DISCONNECTS. COORDINATE EXACT LOCATION WITH UTILITY COMPANY AND ARCHITECT.
- TELEPHONE/CABLE/SECURITY BACKBOARD. BACKBOARD SHALL BE 3/4" X 8' X 4' PLYWOOD WITH TWO COATS FIREPROOF WHITE PAINT. FIELD COORDINATE EXACT LOCATION WITH OWNER IN FIELD. PROVIDE 36" WORKING CLEARANCE. PROVIDE #6 AWG GROUND AND GROUND BAR AT BACKBOARD CONNECTED TO BUILDING GROUNDING SYSTEM. PROVIDE (1) 2"C. FROM TBB TO UTILITY DEMARCATION POINT. COORDINATE EXACT LOCATION WITH UTILITY COMPANY.