

कार्यालय अधिशासी अभियन्ता

प्रान्तीय खण्ड, लो०नि०वि०, बलिया

पत्रांक :- 1424/151-
सेवा में,


दिनांक :- 23/5/17

प्रबन्धक,
निर्मल जीवन पब्लिक स्कूल,
अतरौल इन्दौली, बेल्थरा रोड,
बलिया।

विषय :- निर्मल जीवन पब्लिक स्कूल, अतरौल इन्दौली, बेल्थरा रोड, बलिया के भवन का नेशनल बिल्डिंग के सापेक्ष प्रमाण पत्र के संबंध में।

सन्दर्भ :- आपका पत्र दिनांक 26.04.2017।


उपरोक्त संदर्भित पत्र के सम्बन्ध में इस खण्ड के सहायक अभियन्ता एवं अवर अभियन्ता द्वारा आपके विद्यालय का निरीक्षण किया गया है, जिसकी प्रति संलग्न कर प्रेषित हैं।
संलग्नक—उपरोक्तानुसार।



अधिशासी अभियन्ता
प्रान्तीय खण्ड, लो०नि०वि०,
बलिया


पत्रांक :-


दिनांक :-

1. प्रतिलिपि सहायक अभियन्ता, प्रान्तीय खण्ड, लो०नि०वि०, बलिया को सूचनार्थ प्रेषित।
2. प्रतिलिपि अवर अभियन्ता (प्रा०), प्रान्तीय खण्ड, लो०नि०वि०, बलिया को सूचनार्थ प्रेषित।


अधिशासी अभियन्ता
प्रान्तीय खण्ड, लो०नि०वि०,
बलिया


Headmaster
Nirmal Jeevan Public School
Atrouli, Indoli, Belthara Road
Ballia (U.P.)


प्रबन्धक
निर्मल जीवन पब्लिक स्कूल
अतरौल, इन्दौली, बेल्थरा रोड
बलिया



जाँच प्रमाण-पत्र

निर्मल जीवन पब्लिक स्कूल, अतरौल इन्दौली, बेलथरा रोड, बलिया का भवन
निरीक्षण किया गया। निरीक्षणोपरान्त भवन बिल्डिंग कोड के रिमांक कॉलम के अनुसार पायी गयी।

Sl. No.	Items	Standard	Specification	Remarks
1	Height	3.60 M	N.B.C. 2005 coium 12.18.1.1	3.40 M.
2	Bathroom Height	2.10 M	N.B.C. Clause- 12.4.1	2.00 M.
3	Height of Plinth	0.45 M	N.B.C. Clause- 12.1.1	0.60 M.
4	Stair Width	1.50 M	N.B.C. Clause- 12.18.1.1	1.20 M.
5	Lighting and Ventilation room	1/10 floor area	N.B.C. Clause- as per N.B.C. 2005 Clause- 15.1.2	Yes
6	Fire and life safety	Certified by PHO Ballia	पत्र संख्या-एफ0एस0-18 स्कूल नि0/2016 दिनांक 16.12.2016	Yes
7	Roofs	R.C.C. flate Roof	as per N.B.C. 2005 Clause- 12.19.1	Yes
8	Structure	RCC column and Beam	as per N.B.C. 2005 Clause- 12.19.1	Yes

सहायक अभियन्ता
प्रान्तीय खण्ड, लो0नि0वि0,
बलिया

(Signature)

Principal
Nirmal Jeewan Public School
Great Indaura, Balhara Road, Balia (U.P.)

(Signature)

Nirmal Jeewan Public School
Great Indaura, Balhara Road, Balia (U.P.)

(Signature)

Manager
Nirmal Jeewan Public School
Great Indaura, Balhara Road, Balia (U.P.)

NIRMAN ENGINEER'S ASSOCIATE'S

Jalkal Road, Deoria - 274001 (U.P.) INDIA

Mob: 9415214085, 780722

- Government Approved Valuer
- Chartered Engineer
- Chartered Valuer/Approved Valuer
- Road Engineer for B&G, GDA
- Consultant Rain Water Harvesting
- Panel Valuer of
- Urban Dept. of India
- Construction Bank of India
- Central Bank of Commerce
- L.I.C. * Axis Bank * Bank of India
- L.D.B. * SBI * Bank of Baroda
- Indian Overseas Bank

Certificate

This is Certified that Nirmal Jeevan Public School Atrauli Indauli,

Belthara Road, Ballia Situated at Mauja: Chandaur Sikraur

Pargana: Sikandarpur Garvi, Tehsil: Belthara Road & Distt.: Ballia.

School Building is Examine by our Firm Nirman Engineer's Associate's

Building is Built as per norms of National Building Code -2005 and this

Building is Earthquake Resistant.

Scy

Date: 10.07.2019

Signature

Place : Deoria

Paul

mark

Nirman Engineer's Associate's

Nirman Engineer's Associate's
(Engineer's Architects & Valuers)
Firm Regd. No. - 14/95, Regulated Area
(DEORIA)
Jalkal Road, Deoria - 274001

Nirmal Jeevan
Atrauli Indauli

From Concept Till Completion