

WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
GURUGRAM
TEST REPORT



Test Report No.:- GGN/00417/6/2023 Issued to :-Principal, Kingswood World School, Gurugram Your Reference No. :- spl dated: 20/06/2023 Sample Type:- Chemical Test Name of JE :---- Lab Job Order No. :-417	Issue Date:- 21/06/2023 Location:-Drinking Water of Kingswood World School, Gurugram Collected by :- JP Chouhan Sample collected on & Time:- 20/06/2023 Sample received on:- 20/06/2023 Sample Quantity: 1000 ml
--	---

Test Result

Test started on- 20/06/2023				Test completed on – 21/06/2023		
S No.	Tested Parameter	Results	Unit	Method	Acceptable	Permissible Limit (As per IS 10500:2012) RA 2018
1	Turbidity	<1	NTU	APHA2130 B	1 NTU	5 NTU
2	Taste	Agreeable	-	APHA-2160-C	Agreeable	Agreeable
3	Odour	Agreeable	-	APHA-2150-B	Agreeable	Agreeable
4	Colour	<1	HU	APHA 2120-B	5 HU	15 HU
5	Total Dissolved Solids @180°C	23.7	mg/l	APHA2540 C	500 mg/l	2000 mg/l
6	Total Hardness as CaCO3	10	mg/l	APHA2340 C	200 mg/l	600 mg/l
7	Calcium as (Ca)	<4	mg/l	APHA3500-Ca B	75 mg/l	200 mg/l
8	Magnesium as (Mg)	<2.4	mg/l	APHA3500 Mg B	30 mg/l	100 mg/l
9	Alkalinity	45	mg/l	APHA2320 B	200 mg/l	600 mg/l
10	Chloride as Cl	10	mg/l	APHA 4500 Cl-B	250 mg/l	1000 mg/l
11	Sulphate as (So4)	8	mg/l	APHA 4500-So4- E	200 mg/l	400 mg/l
12	Fluoride as (F)	0.12	mg/l	APHA 4500-D	1.0 mg/l	1.5 mg/l
13	Iron as (Fe)	0.02	mg/l	APHA 3500-Fe B	1.0 mg/l	No Relaxation
14	Nitrate as (No3)	4.33	mg/l	APHA 4500-No3 B	45 mg/l	No Relaxation
15	PH@25°C	7.5	---	APHA 4500-H+ B	6.5-8.5	No Relaxation
16	Conductivity	---	µs	APHA-2510-B		

Specific contractual notes:-

- ◆ The results given above are related to the sample as received and tested in PHED Lab Gurugram.
- ◆ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab Gurugram.
- ◆ The test report can't be used for any publicity or any legal purpose.
- ◆ The samples received shall be destroyed after 15 Days from the date of issue of the certificate.
- ◆ Reliability of water sample lies with sender/collector of water sample.

Reviewed by

SONA FOUNDATION

Trustee

Principal
 Kingswood World School
 Sohna-Gurugram Road,
 (Gurugram)

Authorised Signatory (Kanta Punia)

Chemist


PHED Water Testing Laboratory

Gurugram

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**No. S.H./2023 / 97 Date : 06 - 06 -2023

It is certified that an inspection team headed by Dr.Shailender Kumar , Dy. Civil Surgeon, Gurugram and inspection done by Dr.Vikas Kharti Medical Officer P.H.C Bhondi School health Gurugram of **Kingswood World School, Bhondsi , Gurugram on 23-05-2023** and found that the **Kingswood World School, Bhondsi , Gurugram** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

This Certificate is valid for a period of One Year.

Signature with Seal: 
Name: for CIVIL SURGEON
Designation: GURUGRAM

To
Kingswood World School,
Bhondsi ,
Gurugram.
(Name & Address of the Institution)

SONA FOUNDATION

Trustee


Principal
Kingswood World School
Sohna-Gurugram Road,
(Gurugram)

WATER BACTERIOLOGICAL LAB

DISTRICT CIVIL HOSPITAL, GURUGRAM

D.No. 118/23/naicu

Dated 29/5/23

To

The S.M.O./M.O. Incharge,
GHC/PHC Shandei

SUB : WATER SAMPLES REPORT

In reference to your letter no. 143/23/5/23

Dated 23/5/23 vide which you have sent water samples for bacteriological examination, the result of each is as under :

Sr. No.	Place of Collection	Result
1.	Kingswood World School, Dum Dama Lake Road (Shandei)	FIT
2.		
3.		
4.		
5.		

P.C.C. Presumptive coliforms count 2/100ml/satisfy
* Above samples is are fit unfit for human consumption.

[Signature]
29/5/23

SONA FOUNDATION
[Signature]
Trustee

[Signature]
Principal
Kingswood World School
Sohna-Gurugram Road,
(Gurugram)

[Signature]
D.C.H., Gurugram