

**Project Name:** \_\_\_\_\_

## SLIDE GATES

### All Slide Gates

- Gate stops installed back/front.
- Gate fall protection installed.

### Automated Slide Gates

- Pickets spacing is 2-1/4" or less or gate has mesh / screen.
- No abrupt edges along bottom.
- Entrapment areas are secure with proper safety devices.
- Separate pedestrian access.
- Access Controls 6' from gate.

Completed by: \_\_\_\_\_

Date: \_\_\_\_\_

## SWING GATES

### All Swing Gates

- Gate hinge weld or attachment inspection complete.
- Gate fall protection installed.

### Automated Swing Gates

- Pinch points protected (at gate arm & gate)
- No abrupt edges along bottom.
- Entrapment areas are secure with proper safety devices.
- Separate pedestrian access.
- Access Controls 6' from gate.

Completed by: \_\_\_\_\_

Date: \_\_\_\_\_

This drawing represents gate safety designs for reference only. It does not serve as a guarantee of the safety or security of your gate. The actual implementation should be conducted following local regulations, building codes, and safety standards. We strongly advise consulting with a professional installer or knowledgeable authority to ensure compliance and safety in all stages of gate installation and operation. Always abide by your local regulations and laws.

