

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, AVERAGE**

The Texas Commission on Environmental Quality (TCEQ) has notified the **CITY OF BEVIL OAKS PWS 1230049** public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in;

- 4Q2023 of .082 mg/L for 7175 CARROLL LANE, BEVIL OAKS (DBP2-01)

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:(TTHM)
The disinfectant residual was lowered to reduce the formation and additional flushing will occur at the deadend Lines.

<corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: __Sabrenna Crain_____

Area Code + Phone number: __409-753-2126_____

Posted /Delivered on: __January 29, 2024_____
