

- (c) Toilet facilities for liquor dispensers.
- (1) The respective toilet rooms and entrances for the two sexes shall be separate in all cases.
  - (2) Toilet facilities shall be provided so as to be readily accessible, within the establishment.
  - (3) Separate water-closets and lavatories shall be provided for each sex.
  - (4) Every toilet room or room containing a water-closet or urinal shall be properly ventilated.

Table V

Liquor Dispensers

Water-Closets			Urinals		Lavatories	
No. of Each Sex	Male	Female	Total No. of Persons	Male	Total No. of Persons	No. of Fixtures per Toilet Room
1-50	1	1	1-150	1	1-150	1
51-150	2	2			151-200	2
151-300	3	4			201-400	3
Over 300	One for each 200 additional persons	One for each 200 additional persons	Over 150	One for each 150 additional persons	Over 400	One for each 400 additional persons

(d) Natural ventilation. If natural ventilation alone is provided, windows and other ventilation openings shall be located to provide effective ventilation. The minimum net open area for such openings shall be as follows: