



**GENERAL NOTES**

Precast concrete shall be exposure Class S and meet min compressive strength of 35MPA

Cement: Type GU  
 Air Category: 4.0% - 7.0%  
 Aggregate: CSA/CAN A23.4 Maximum Size: 20mm  
 Admixtures: CSA/CAN A23.4  
 Reinforcing: Grade 400W CSA G30.18-09  
 Inserts/Embeds: As noted in drawing details

Manufacture of precast concrete units shall be in accordance with specification CSA A23.4

**\*\* LEKO PRECAST LTD SHALL NOT BE RESPONSIBLE FOR ANY INSTALLATION PRACTICES FOLLOWED ON-SITE UNLESS PERFORMED BY LEKO PRECAST LTD \*\***

2,680Kg (5,900 LBS)  
 1260L (280IG)



**42" x 7ft. PUMP CHAMBER ASSEMBLY**

DRAWN BY: JA	CHECKED BY:	APPROVED BY:	DATE: DECEMBER 2015
ASSEMBLY DWG.	PREVIOUS DWG.	DRAWING NO. S0233	REVISION 1
SCALE: 1:20	ISOMETRIC: N/A		
DO NOT SCALE THIS DRAWING			