

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Inverness Water and Sanitation District

## Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on 03/23/2026 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Required Language	Date Correction is Required	Steps We Are Taking
F326 - Supplier failed to perform or document comprehensive tank inspections.	Inadequately maintained storage tanks, identified through inspections, may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.	08/19/2026	The District did not have a comprehensive tank inspection performed in 2021, comprehensive tank inspections are to be performed every 5 years. The District has contracted a diving company to perform a comprehensive tank inspection and will be completed before 08/31/2026.
M613 - Monitoring and Reporting	N/A	08/19/2026	The District did not have an adequate and/or complete backflow report for 2024 and has since completed the report and submitted to CDPHE.
M611 - Supplier has either permitted or installed a cross	Uncontrolled cross connections can lead to a back pressure or siphonage event that may allow	08/19/2026	The District had four (4) uncontrolled cross-connections due to failed and/or missing backflow

<p>connection and was unable to control the cross connection within the 120 day deadline, or by a Department approved alternative schedule.</p>	<p>contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.</p>		<p>testing results. The District has issued disconnect notices to these properties and will disconnect service or the property will provide the District with a passing backflow test for each backflow that failed or missing. The District has given the properties until 06/22/2026 to comply before water services are disconnected.</p>
---	---	--	--

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the inspection it was identified that we did not complete all monitoring/testing, were not monitoring correctly, or were monitoring at an inappropriate location. Therefore we cannot be sure of the drinking water quality during that time.

We also failed to notify you of the violation/situation in a timely manner.

**What does this mean? What should I do?**

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving these problems by **08/31/2026**. For more information, please contact **Nolan Cunningham** at [nolan.cunningham@invernesswater.org](mailto:nolan.cunningham@invernesswater.org) or **7208002826**, or **58 Inverness Drive East, Ste 100, Englewood, CO 80112**.

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

This notice is being sent to you by: Inverness Water and Sanitation District - CO0203012  
Date distributed: **06/04/2026**