



PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO MONITOR

ESTE INFORME CONTIENE INFORMACION IMPORTANTE ACERA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Monitoring Requirements Not Met for Beaver Falls Municipal Authority

Our water system violated a monitoring requirement in 2018. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

What should I do?

There is nothing you need to do at this time.

What Happened? What was done?

On September 25, 2018, one of our eight online filter turbidity analyzers was broken, which required grab samples from that specific filter effluent every 4 hours. During that time, the 7pm grab sample was missed. When this discovery was made, a sample was taken immediately at 11pm on September 25, and the turbidity was in compliance. Since then, the online analyzer was replaced and is recording as required.

For more information, please contact Tracy Price at (724)847-7387

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartment, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the Beaver Falls Municipal Authority.

PWS ID#: 5040012

Date Distributed: 3/13/19