



AMC GROUP OF EDUCATIONAL INSTITUTIONS
Accredited by NAAC B++ Grade (2.79)
Affiliated to Calicut University
AMC Building, Kothayur Road, Manissery PO, Ottapalam
Palakkad Dt, KERALA, INDIA. Pin : 679 521.
Tel : 0466 2226527, Mob : 9995427765

To
The AICTE Authorities

Subject: Submission of Fire and Safety Documents – Compliance to EVC Observations

Respected Sir/Madam,

With reference to the observations made by the Expert Visit Committee (EVC) during the AICTE Approval Process 2026–2027, we hereby submit the compliance documents related to Fire and Safety requirements.


As noted in the EVC report, the earlier Fire Safety document was not accepted as it was in the local language and not considered valid. In this regard, we wish to submit the following for your kind consideration:


1. The previously submitted Fire & Rescue Department document has now been officially translated into English and duly notarized. The translated and notarized copies are enclosed for verification.
2. As advised, the institution has completed the required fire safety installations in the campus. The installation has been carried out by Southern Fire Services, and a valid certificate confirming the installation and servicing of fire extinguishers has been obtained and enclosed.
3. As per the communication from the Fire & Rescue Department, it is clarified that a No Objection Certificate (NOC) is required only for buildings having a floor area above 1000 square meters or a height above 15 meters. Since our building does not fall under these categories, obtaining an NOC is not mandatory. The relevant translated document supporting this is also enclosed.

We hereby confirm that necessary fire safety measures have been implemented and are being maintained in accordance with applicable norms and safety standards.

We request you to kindly consider the enclosed documents and update the compliance status accordingly.
Thanking you,

Yours faithfully,
For AMC Group of Educational Institutions


Dr. BYJU. K
M.Com (Double), MBA, CWA, M.Phil, PhD
PRINCIPAL
AMC GROUP OF EDUCATIONAL INSTITUTIONS
AFFILIATED TO CALICUT UNIVERSITY
MANISSERY, PIN - 679 521



Dr.Byju K
Principal

നോൺ ജുഡീഷ്യൽ

NON JUDICIAL

₹ 200

₹ 200

കേരള സർക്കാർ
GOVERNMENT OF KERALA
e-Stamp

e-Stamp Serial Number : 20262700000021000

Verification Code : 838753923V

Govt. Reference No.(GRN)	: KL000141025202627E
Purpose	: Affidavit
Amount of Stamp Paper Purchased in Numeral	: ₹ 200
Amount of Stamp Paper Purchased in Words	: Rupees Two Hundred
Stamp Paper Purchased on	: 01/04/2026 15:47:56
First Party Name	: Kodakkattuthodi Madom Ramaswami
First Party Address	: Trisha Charitable Trust, Manisseri Po
Second Party Name	: AICTE
Second Party Address	: Nelson Mandela Marg, New Delhi
Vendor Code & Name	: 21022069 - Sudha C
Treasury Code & Name	: 2102 - Sub Treasury, Ottappalam

Please write or type below this line

AFFIDAVIT

I, KODAKKATTUTHODI MADOM RAMASWAMI, Managing Trustee and Chairman of TRISHA CHARITABLE TRUST, Son of C Venkidachalam, aged 85 years, resident of Kodakkattuthodi Madom, Chorottur, Manisseri Post, Ottapalam, Palakkad District, Kerala – 679521, do hereby solemnly affirm and declare as under:

1. That I am the authorized signatory of TRISHA CHARITABLE TRUST and I am well conversant with the facts of the case.
2. That the institution AMC Group of Educational Institutions is running in an owned building at Kothayur Road, Manisseri Post, Ottapalam, Palakkad District, Kerala – 679521.



For TRISHA CHARITABLE TRUST

[Signature]
 K. RAMASWAMI
 CHAIRMAN & M.G-TRUSTEE



This can be verified by https://estamp.treasury.kerala.gov.in/index.php/estamp_search using e-Stamp Serial Number and Verification Code.

In case of any discrepancy, please inform the competent authority.

[Signature]
 C. SUDHA
 TEMPORARY VENDOR
 OTTAPPALAM



3. That the total built-up area of the building intended for classrooms is 267.74 m² (less than 1000 m²).
4. That I undertake that despite the area being less than 1000 m², the building fulfils the regulatory norms and provides sufficient academic space for the approved intake of students.
5. That the building is safe, structurally sound, and possesses all necessary approvals from local municipal authorities.
6. That I shall increase the area as per university norms within the stipulated time, if required.

Dated this the 1st day of April 2026 For TRISHA CHARITABLE TRUST

(Handwritten Signature)

DEPONENT K. RAMASWAMI
CHAIRMAN & M.G TRUSTEE
KODAKKATTUTHODI MADOM RAMASWAMI



Executed and Signed before me by the executant/s on this the 1st day of April 2026 at my office at Ottappalam.



(Handwritten Signature)

AJEET SREEDHARAN
ADVOCATE & NOTARY
Roll No: K/865/2004
Ottappalam, Palakkad (Dt), Kerala, India - 679101
Mob: 9400621051
advajetsreedharan@gmail.com

Notarial Register Particulars
Sl. No. 96
Page No. 18 Book No. 1

No. A2-6654/18

Date 28/06/2018

Addressee

Assistant Divisional Officer
Fire & Rescue Services, Palakkad

Sir,

Sub. :- Regarding the issuance of No Objection Certificate of the Fire Department for allotment of building number to a building for educational purposes

Ref. :- Application Sri Ramaswami, Chairman Trisha Charitable Trust, Kodakkatuhodi Madom, Chorotoor (Allied Management College) dated 06/06/2018 numbered as above

The building plan and site plan of the said building are certified by 03 Set Secretary and Assistant Engineer, Technical Section and are enclosed for further action

Sincerely


Secretary

Vaniyankulam Grama Panchayat

Enclosure:

3 copies of the plan

Transmitted Copy of Doc No A2-6654/18 issued
by Secretary, Vaniyankulam Grama Panchayat.





AJEET SREEDHARAN
ADVOCATE & NOTARY
Roll No: K/865/2004
Ottappalam, Palakkad (Dt), Kerala, India - 679101
Mob: 9400621051
advajetsreedharan@gmail.com

"Administrative Language - Mother Tongue"

No. C-412/2019

Station Officer

Fire & Rescue Station

Shornur

Secretary

Grama Panchayat Office

Vaniyankulam

Fire & Rescue Station: Shornur

Date: 01/07/2019

PH:0466222501

E-mail:snr.frs@kerala.gov.in

- Subject : Fire & Rescue Station – Shoranur - Return of Fire NOC Application - Regarding
Ref : 1. G.O.(P) No. 81/2017 L.S.G.D Date: 31/10/2017
2. G.O.(P) No. 82/2017 L.S.G.D Date: 31/10/2017
3. Letter of Hon. Director General. Fire & Rescue Services Thiruvananthapuram dated 16/04/2019, No. 613 2-9400/16
4. Your letter No. A 2-6654/18 Date: 28/06/2019

As per (1,2,3) referred above, except for the buildings falling under the categories of Assembly, Hazardous and Industrial, it is directed that the No Objection Certificate of this department is required to be obtained only for the buildings whose floor area is above 1000 M' or whose height is above 15 meters. On the basis of this, since this building does not fall under the above categories, the no-objection certificate of this department is not required and the application and related documents received at this station are returned as per (3) above. However, fire protection systems as per NBC Part-4 should be installed in the building and they should be made operational and maintained from time to time. Other safety standards should also be followed in the building.

Yours faithfully

Seal of

Station Officer
Fire and Rescue Station
Govt. Press (P.O.)
Shoranur - 679122

*Transacted copy of Dec. No. C-412/2019 issued
by Station Officer, Fire & Rescue Stn, Shoranur.*



[Signature]
AJEET SREEDHARAN
ADVOCATE & NOTARY
Roll No: K/865/2004
Ottappalam, Palakkad (Dt), Kerala, India - 679101
Mob: 9400621051
advajeetsreedharan@gmail.com



SOUTHERN FIRE SERVICES

Mfrs. of Fire Extinguishers & Allied Requisites

Regd. & Sales Office:
Pazhayannur
Thrissur Dt. Kerala
Mob: 9847695996

Date 05/4/26

Ref: SFS/GEN/2026

Certificate

To whom so ever it may concern

Sirs,

This is to certify that we Have Supplied Serviced Refilled fire protection equipments of
Ms. AMC GROUP OF EDUCATIONAL INSTITUTIONS
ACCREDITED by NAAC WITH B+ GRADE (2.79)
as mentioned below AF AFFILIATED TO CALICUT UNIVERSITY
AMC BUILDING, MANISSERY, OTTAPALAM.

Sl. No.	Type of Extinguishers	Capacity	Nos.
1	ABC Powder type	4kg	6 nos
2	CO ₂ type	2kg	1 no

Serviced/Refilled on 5/4/2026

Next Servicing/Filling due on 4/4/2027

Thanking you

Yours Faithfully

For Southern Fire Services


Manager



SOUTHERN FIRE SERVICES

Mfrs. of Fire Extinguishers & Allied Requisites

Regd. & Sales Office:
Pazhayannur
Thrissur Dt. Kerala
Mob: 9847695996

Date: 05-04-2026

CERTIFICATE

Ref: SFS/GEN/2026

so ever it may concern

Sir,

This is to certify that we Have Supplied Serviced Re ed fire pro on equipment's of AMC GROUP OF EDUCATIONAL INSTITUTIONS, Accredited by NAAC with B++ Grade (2.79) Affiliated to Calicut University AMC Building, KOTHAYUR Road, MANISSERY PO, OTTAPALAM, PALAKKAD Dt.as mentioned below.

SINo.	Type of Extinguishers	Capacity	Nos
1	ABC POWDER TYPE	4 Kg	6 NOS
2	CO ₂ TYPE	2 Kg	1 NOS

Serviced Refilled on 05-04-2026

Next Servicing / Filling due on 04-04-2027

Thanking you
Yours faithfully
For Southern Fire Services
For Southern Fire Services

Proprietor





സെക്രട്ടറി Secretary
വാണിയംകുളം ഗ്രാമ പഞ്ചായത്ത്

Vaniyamkulam Grama Panchayat Office

വാണിയംകുളം ഗ്രാമ പഞ്ചായത്ത് ഓഫീസ്
Vaniyamkulam Grama Panchayat Office (PO), Ottappalam ഭൂപാലം
Palakkad - പാലക്കാട് - 679522. Phone: 0466222727, 9196047145
e-Mail: vniyamkulampanchayat@gmail.com
WebSite: www.isykerala.gov.in/vaniyamkulampanchayat

നമ്പർ എ2-6654/18

തീയതി 28/06/2019

സീക്രട്ടറിയ്ക്ക്

അസിസ്റ്റന്റ് ഡിവിഷണൽ ഓഫീസർ
ഫയർ & റെസ്ക്യൂ സർവ്വീസസ്, പാലക്കാട്

സർ,

വിഷയം:- വിദ്യാഭ്യാസ ആവശ്യത്തിനുള്ള കെട്ടിടത്തിന് കെട്ടിട നമ്പർ അനുവദിക്കുന്നതിന് അനിശ്ചിത
വിഭാഗത്തിൽനിന്നെ നിരാകേക്ഷ സാക്ഷ്യപത്രം ലഭ്യമാക്കുന്നത് സംബന്ധിച്ച്

സൂചന:- ശ്രീ രാമസ്വാമി. ചെമ്പൻമാൻ, തൃഷ ചാർട്ടർഡ് സ്കൂൾ, കോടക്കാട്ട് തൊടി മഠം, ചോറോട്ടൂർ
(അലൈഡ് മാനേജ്മെന്റ് കോളേജ്) എന്നിവിടെ 06/06/2018 തീയതിയിലെ മേൽ നമ്പർ
അപേക്ഷ

പ്രസ്തുത കെട്ടിടത്തിന്റെ ബിൽഡിംഗ് പ്ലാൻ, സൈറ്റ് പ്ലാൻ എന്നിവ 03 ട്രസ്റ്റ് സെക്രട്ടറിയും, സാമൂഹിക
വിഭാഗം ഓഫീസറും എഞ്ചിനീയറും സാക്ഷ്യപ്പെടുത്തി തുടർ നടപടികൾക്കായി ഉള്ളടക്കം ചെമ്പൻമാൻ.

വിശ്വസ്തപ്രമാണം.

സെക്രട്ടറി

വാണിയംകുളം ഗ്രാമപഞ്ചായത്ത്

ഉള്ളടക്കം
പ്ലാൻ, സൈറ്റ് പ്ലാൻ



സെക്രട്ടറി
വാണിയംകുളം ഗ്രാമപഞ്ചായത്ത്
വാണിയംകുളം പി.ഒ.
പാലക്കാട് തിരുവിതാംകൂർ - 679522
ഫോൺ . 9496047145

"ഭരണഭാഷ - മാതൃഭാഷ"

നം.സി - 412/2019
സ്റ്റേഷൻ ഓഫീസർ
അഗ്നിരക്ഷാനിലയം
ഷൊർണ്ണൂർ

അഗ്നിരക്ഷാനിലയം : ഷൊർണ്ണൂർ
തീയതി : 01/07/2019
PH:04662222501
E-mail:snr.frs@kerala.gov.in

സെക്രട്ടറി
ഗ്രാമപഞ്ചായത്ത് കാര്യാലയം
വാണിയംകുളം

വിഷയം: അഗ്നിരക്ഷാനിലയം- ഷൊർണ്ണൂർ- ഫയർ എൻ.ഒ.സി അപേക്ഷ മടക്കി നൽകുന്നത്- സംബന്ധിച്ച്

- സൂചന :
1. ജി.ഒ.(പി) നം. 81/2017 എൽ.എസ്.ജി.ഡി തീയതി : 31/10/2017
 2. ജി.ഒ.(പി) നം. 82/2017 എൽ.എസ്.ജി.ഡി തീയതി : 31/10/2017
 3. ബഹു. ഡയറക്ടർ ജനറൽ . ഫയർ & റെസ്ക്യൂ സർവീസസ് തിരുവനന്തപുരം അവർകളുടെ 16/04/2019 തീയതിലെ കത്ത് നം. എഫ് 2- 9400/16
 4. അങ്ങയുടെ കത്ത് നം എ 2-6654/18 തീയതി : 28/06/2019

A3
മേൽസൂചി
മേൽസൂചി

മേൽസൂചന (1,2,3) പ്രകാരം അസ്സംബ്ലി, ഹസാർഡസ്, ഇൻഡസ്ട്രിയൽ എന്നീ വിഭാഗങ്ങളിൽപ്പെടുന്ന കെട്ടിടങ്ങൾക്കൊഴികെ കെട്ടിടത്തിന്റെ അടിത്തറ വിസ്തീർണ്ണം 1000 M² -ന് മുകളിലോ ഉയരം 15 മീറ്ററിന് മുകളിലോ വരുന്നതായ കെട്ടിടങ്ങൾക്ക് മാത്രം ഈ വകുപ്പിന്റെ നിരാക്ഷേപസാക്ഷ്യപത്രം വാങ്ങേണ്ടതായിട്ടുള്ളുവെന്ന് നിർദ്ദേശിച്ചിരിക്കുന്നു. ആയതിന്റെ അടിസ്ഥാനത്തിൽ ടി കെട്ടിടം മേൽപ്പറഞ്ഞ വിഭാഗങ്ങളിൽ ഉൾപ്പെടാത്തതിനാൽ ഈ വകുപ്പിന്റെ നിരാക്ഷേപസാക്ഷ്യപത്രമാവശ്യമില്ല എന്ന് കണ്ട് ഈ നിലയത്തിൽ ലഭിച്ച അപേക്ഷയും അനുബന്ധരേഖകളും മേൽസൂചന(3)പ്രകാരം മടക്കി നൽകുന്നു.എന്നാൽ ടി കെട്ടിടത്തിൽ എൻ.ബി.സി പാർട്- 4 പ്രകാരം അഗ്നിപ്രതിരോധ സംവിധാനങ്ങൾ സ്ഥാപിക്കേണ്ടതും അവ കാലാകാലങ്ങളിൽ പ്രവർത്തനസജ്ജമാക്കി പരിപാലിക്കേണ്ടതുമാണ്. കെട്ടിടത്തിൽ മറ്റ് സുരക്ഷാ മാനദണ്ഡങ്ങളും പാലിക്കേണ്ടതാണ്.

എന്ന്
വിശ്വസ്തതയോടെ

(Signature)
സ്റ്റേഷൻ ഓഫീസർ
ഫയർ & റെസ്ക്യൂസ്റ്റേഷൻ
ഗവ: പ്രസ്റ്റ് (പി.ഒ)
ഷൊർണ്ണൂർ-670 122

