

Compliance Statement

No. 2025-563

Data communication cable, Category 6A

Company

TELUNIX s.r.o. Gogol'ova 18 851 01 Bratislava Slovakia

Product description

Screened cable (F/FTP) characterised up to 650 MHz* Horizontal floor wiring cable, 100 Ω 4 individually foil screened twisted pairs with overall foil screen Flame retardant, halogen free

Product identification

TELUNIX FFTP CAT 6A LSZH LAN Cable P/N: TX/LNFFTP6ALS500GR

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-E:2024

Standards for flammability, halogen acidity, and smoke performance

• IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2025 (Ed. 2.0)

* Transmission parameters comply with extended Cat. 6_A limits up to 650 MHz.

- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report 12527206-01, DANAK-19/25258

EC Cabling product ID

CS valid until 1 October 2026

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 29 September 2025

Nis Jepsen

Specialist, Project Manager

Lars Lindskov Pedersen

Senior Team Leader, Test Manager

