

Attestation of Conformity

No. 2026-014

Cables for use in construction works Reaction to fire class E_{ca}

Company

TELUNIX s. r. o.
Gogol'ova 18
851 01 Bratislava
Slovakia

Product description

Optical fibre cable with 6 tight buffered fibres, LSZH

Product identification

Fiber Optic Cable - 6 Cores Tight-Buffered Distribution Cable – GJPFJH Type Single Mode G652D LSZH
Part no. TX/FOC- GJPFJH-6B1.3SM

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015, A11:2016 and A12:2020
- EN 13501-6:2018 including amendment A1:2022

Reaction to fire classification

Class E_{ca}

Technical report

12521543-01, DANAK-19/25411

EC Cabling product ID


8166

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 14 January 2026



Nis Jepsen
Specialist, Project Manager



Lars Lindskov Pedersen
Senior Team Leader, Test Manager