

HDR



# Centrifuge Operational Adjustments Result in Cost Savings Opportunities at NEORSD

Midwest Biosolids Association, 2<sup>nd</sup> Annual Conference

Brian Flannagan, NEORSD  
Adam Parmenter, HDR

May 21, 2025

# Agenda

1. **NEORSD Background**
2. **Testing Purpose & Goals**
3. **Centrifuge Operation Fundamentals**
4. **Centrifuge Optimization Test Results**
5. **Next Steps**



# NEORSD Background




# NEORSD – Northeast Ohio Regional Sewer District

**Southerly WWTP is the largest of NEORSD's three wastewater plants**


**Average daily flow of 120 MGD, Max day 480 MGD (Secondary Treatment)**

**Centrifuge Dewatering**

**Incineration**




# Process Flow of Renewable Energy Facility



# Gravity Thickener (GT) Operations

- Receives Primary Sludge (PS) & Excess Activated Sludge (EAS)
- GT pumping philosophy has been to keep a <5-foot blanket to maintain a high total solids content.
- Total solids out of GTs up to 6% TS in low flow conditions
- GT Issues in Wet Weather



# Testing Purpose & Goals




# Purpose & Goal of Testing

- Problem:
  - Wet weather events flush thinner sludge through the process and reduce the GTs effectiveness. This impacts normal centrifuge operations.
- Goals:
  - Determine if a consistently thinner sludge to dewatering centrifuges have negative impacts centrifuge operation
  - Secondary Goal of determining additional Operations “Levers to Pull” and Energy Saving opportunities



# Centrifuge Thin Sludge Testing Plan

- Simulate a low solids sludge concentration (thin sludge) into a centrifuge, as low as 0.5% TS
- Determine any needed setpoint changes for successful performance




## Six Individual Tests

- Test #1 - Thin Sludge, Low Solids Loading Rate (Minimum Flow Rate)
- Test #2 - Thin Sludge, High Solids Loading (Maximum Flow Rate)
- Test #3 - Polymer Reduction Optimization (Cost Saving)
- Test #4 - Centrifuge Higher Bowl Speed (Cake Solids Control)
- Test #5 - Centrifuge Lower Bowl Speed (Energy Savings & Cake Solids Control)
- Test #6 - Centrifuge Lower Torque (Cake Solids Control & Centrate Quality)

# Centrifuge Thin Sludge Testing Setup


- Polymer Jar Testing
  - Confirmed existing polymer creates good floc at as low as 0.5% TS feed solids w/ NPW
  - Small polymer dose increase may be needed at thinner sludge feed rates
- Determine NPW Injection Location Into Centrifuge Feed







# Centrifuge Operation Fundamentals

# Centrifuge Anatomy




# Centrifuge Anatomy Breakdown





# Centrifuge Anatomy Scroll Removed from Bowl



Beach Pressure Zone  
Start

Scroll inside Bowl




# Centrifuge Anatomy – Typical Scroll

Sludge inlet


Hardened Tiles

Beach Start






# Centrifuge Anatomy – Typical Scroll Flight & Hardened Tiles



Hardened Tiles

Sludge inlet


# Centrifuge Anatomy



Animations Complements of Alfa-Laval



# Centrifuge Anatomy




The decanter centrifuge is like a clarifier.....






# Operational Control – Differential Speed

- Scroll Rotates at a consistent different speed than the bowl
  - Greater speed difference = Faster solids discharged & less residence time
  - Lower speed difference = Higher %TS & longer residence time



# Operational Control - Torque

- Scroll Speed Changes Based on Resistance from Solids
- Higher % TS – higher torque
- Allows for Consistent Cake
- Variations in Torque
  - Changes in feed characteristics
  - Polymer dosage



# Centrifuge Optimization Test Results

# Test #1 - Thin Sludge, Low Solids Loading Rate (Minimum Flow Rate) Findings:

- Stable performance 1,500 lbs/hr (Machine's minimum rated throughput)
- Stable performance at 0.8% TS
- No torque, centrate quality, or cake total solids changes.
- Centrifuge can handle thinner sludge during wet weather events without negative impacts

DATE, TIME, & RUN No.			PROCESS READINGS					LAB RESULTS		CALC'D RESULT
Date	Time	Run Number	Feed Rate gpm	NPW Rate gpm	Feed + NPW gpm	Scroll Differ. (RPM)	Scroll Torque (%)	Feed % TS	Cake % TS	Feed Loading dry lbs/hr
Tuesday, July 30, 2024	12:00	1	135	0	135	2.0	50	3.62	31.52	2445
Tuesday, July 30, 2024	13:15	2	135	50	185	2.0	50	Not Taken	Not Taken	#VALUE!
Tuesday, July 30, 2024	13:50	3	135	100	235	2.0	50	1.47	33.00	1728
Tuesday, July 30, 2024	13:50	4	135	100	235	2.0	50	1.62	Not Taken	1904
Tuesday, July 30, 2024	14:00	5	135	100	235	2.0	50	1.55	Not Taken	1822
Tuesday, July 30, 2024	14:30	6	135	150	285	2.0	50	3.74	Not Taken	2526
Tuesday, July 30, 2024	15:00	7	135	158	293	2.0	50	3.74	34.11	2526
Tuesday, July 30, 2024	15:00	8	135	158	293	2.0	50	1.14	Not Taken	1671
Tuesday, July 30, 2024	15:00	9	135	158	293	2.0	50	0.84	Not Taken	1231
Tuesday, July 30, 2024	15:00	10	135	158	293	2.0	50	1.13	Not Taken	1656
Tuesday, July 30, 2024	16:20	11	100	156	256	2.0	50	1.33	37.42	1703
Tuesday, July 30, 2024	16:20	12	100	156	256	2.0	50	1.20	Not Taken	1537
Tuesday, July 30, 2024	16:20	13	100	156	256	2.0	50	1.18	Not Taken	1511



## Test #2 - Thin Sludge and High Solids Loading (Maximum Flow Rate) Findings:

- Stable performance up to 350 GPM Feed (Machine's maximum rated hydraulic throughput)
- Stable performance at as low as 1.8% TS Feed
  - NPW Injection limited lower %TS Feed testing
- No torque, centrate quality, or cake total solids changes.
- Centrifuge can handle thinner sludge during wet weather events without negative impacts at high flow rates

DATE, TIME, & RUN No.			PROCESS READINGS					LAB RESULTS		CALC'D RESULT
Date	Time	Run Number	Feed Rate gpm	NPW Rate gpm	Feed + NPW gpm	Scroll Differ. (RPM)	Scroll Torque (%)	Feed % TS	Cake % TS	Feed Loading dry lbs/hr
Wednesday, July 31, 2024	07:00	1	140	0	140	2.0	50	4.84	35.56	3390
Wednesday, July 31, 2024	07:20	2	185	0	185	2.0	50	4.84	Not Taken	4479
Wednesday, July 31, 2024	10:15	3	185	75	260	2.0	50	2.73	35.78	3551
Wednesday, July 31, 2024	10:15	4	185	75	260	2.0	50	2.71	35.78	3525
Wednesday, July 31, 2024	11:30	5	185	159	344	2.0	50	1.79	39.74	3080
Wednesday, July 31, 2024	11:30	6	185	159	344	2.0	50	1.83	39.74	3149
Wednesday, July 31, 2024	12:15	7	185	159	344	2.0	50	2.04	39.74	3510
Wednesday, July 31, 2024	12:15	8	185	159	344	2.0	50	2.38	39.74	4096

## Test #3 - Polymer Reduction Optimization (Cost Saving) Findings:

- Polymer dose was reduced to as low as 5.2 lbs/dt while still maintaining a 95% solids capture rate.
- 30% potential reduction in polymer use possible without compromising performance.

DATE, TIME, & RUN No.			PROCESS READINGS							POLYMER INFO					LAB RESULTS		CALCULATED RESULTS		
Date	Time	Run Number	Feed Rate gpm	NPW Rate gpm	Feed + NPW gpm	Polymer to Sludge Ratio	Poly Rate gpm	Scroll Differ. (RPM)	Scroll Torque (%)	Neat Poly %active	Intro Point	Dilute Soln %active	Post Dilution gpm	Dilute Soln gpm	Feed % TS	Cake % TS	Feed Loading dry lbs/hr	Solids Recovery %	Polymer Dose active lbs/ton
Wednesday, July 31, 2024	3:15	1	160	0	160	15.50%	24.8	2.0	50	39.0	3B Inlet	0.11	0	24.8	4.63	37.10	3706	100.0	7.4
Wednesday, July 31, 2024	3:25	2	160	0	160	14.75%	23.6	2.0	50	39.0	3B Inlet	0.11	0	23.6	4.63	34.47	3706	97.9	7.0
Wednesday, July 31, 2024	3:35	3	160	0	160	14.25%	22.8	2.0	50	39.0	3B Inlet	0.11	0	22.8	4.63	38.06	3706	97.7	6.8
Wednesday, July 31, 2024	3:45	4	160	0	160	13.00%	20.8	2.0	50	39.0	3B Inlet	0.11	0	20.8	4.63	39.73	3706	97.9	6.2
Wednesday, July 31, 2024	3:55	5	160	0	160	12.00%	19.2	2.0	50	39.0	3B Inlet	0.11	0	19.2	4.63	38.96	3706	96.8	5.7
Wednesday, July 31, 2024	4:05	6	160	0	160	11.00%	17.6	2.0	50	39.0	3B Inlet	0.11	0	17.6	4.63	39.33	3706	95.0	5.2
Wednesday, July 31, 2024	4:15	7	160	0	160	10.00%	16.0	2.0	50	39.0	3B Inlet	0.11	0	16.0	4.63	36.12	3706	89.9	4.8

## Test #4 - Centrifuge Higher Bowl Speed (Cake Solids Control) Findings:

- Bowl speed increased from 2300 RPM to 2500 RPM
- No significant operational benefits
- Introduces higher energy consumption and potential additional wear-and-tear issues
- No improvements in cake solids control or performance

DATE, TIME, & RUN No.			PROCESS READINGS				LAB RESULTS			CALC'D RESULTS		Motor Data
Date	Time	Run Number	Feed Rate gpm	Scroll Differ. (RPM)	Scroll Torque (%)	Bowl Speed (RPM)	Feed % TS	Cake % TS	Centrate % TS	Feed Loading dry lbs/hr	Solids Recovery %	Bowl Motor Amps
Thursday, August 1, 2024	9:00	1	160	2.0	50	2300	4.06	39.09	0.06	3250	98.7	49.6
Thursday, August 1, 2024	10:10	2	160	2.0	50	2400	4.06	37.14	0.08	3250	98.2	51.0
Thursday, August 1, 2024	10:20	3	160	2.0	50	2500	4.06	37.75	0.00	3250	100.0	52.5

## Test #5 - Centrifuge Lower Bowl Speed (Cake Solids Control & Centrate Quality) Findings:

- The bowl speed was decreased from the standard 2300 RPM to 2000 RPM
- Lower bowl speed maintains desired cake concentration of >28% TS
- An 11-amp energy savings per centrifuge
- Lowering the bowl speed can reduce wear on the centrifuge bearings and extend equipment life

CENTRIFUGE No. 3B													
DATE, TIME, & RUN No.			PROCESS READINGS				LAB RESULTS			CALC'D RESULTS		Motor Data	
Date	Time	Run Number	Feed Rate gpm	Scroll Differ. (RPM)	Scroll Torque (%)	Bowl Speed (RPM)	Feed % TS	Cake % TS	Centrate % TS	Feed Loading dry lbs/hr	Solids Recovery %	Bowl Motor Amps (%)	Bowl Motor Amps (A)
Thursday, August 1, 2024	9:00	1	160	2.0	50	2300	4.06	39.09	0.06	3250	98.7	49.6	149.8
Thursday, August 1, 2024	10:45	1	160	2.0	50	2200	4.06	39.47	0.14	3250	96.9	47.8	144.4
Thursday, August 1, 2024	11:10	2	160	2.0	50	2100	4.06	38.40	0.18	3250	96.0	46.7	141.0
Thursday, August 1, 2024	11:30	3	160	2.0	50	2000	4.06	39.23	0.12	3250	97.3	45.9	138.6
Thursday, August 1, 2024	11:30	4	160	2.0	50	2000	4.06	37.91	0.09	3250	98.0	45.9	138.6



## Test #6 - Centrifuge Lower Torque (Cake Solids Control & Centrate Quality)

- Lowered torque from 50% to 42%
- Lowering the torque resulted in a wetter cake which could be useful when cake total solids are too dry for the incinerator

CENTRIFUGE No. 3B											
DATE, TIME, & RUN No.			PROCESS READINGS				LAB RESULTS			CALC'D RESULTS	
Date	Time	Run Number	Feed Rate gpm	Scroll Differ. (RPM)	Scroll Torque (%)	Bowl Speed (RPM)	Feed % TS	Cake % TS	Centrate % TS	Feed Loading dry lbs/hr	Solids Recovery %
Thursday, August 1, 2024	12:30	1	250	2.0	50	2300	4.06	39.09	0.06	5077	98.7
Thursday, August 1, 2024	14:20	2	250	3.0	48	2300	4.06	38.61	0.24	5077	94.7
Thursday, August 1, 2024	14:30	3	250	4.0	46	2300	4.06	36.20	0.20	5077	95.6
Thursday, August 1, 2024	14:45	4	250	4.0	44	2300	4.06	35.29	0.21	5077	95.4
Thursday, August 1, 2024	14:55	5	250	4.0	42	2300	4.06	33.01	0.21	5077	95.4

# Next Steps

# Conclusion

- Optimization is a Continuous Process
- Understand Performance Links Among Various Parameters
- Maintain Operating Records to Identify Process & Operational Changes
- Take Action!



# THANK YOU

## **Centrifuge Operational Adjustments Result in Cost Savings Opportunities at NEORSD**

Brian Flannagan, NEORSD

[FlanaganB@neorsd.org](mailto:FlanaganB@neorsd.org)

Adam Parmenter, HDR

[Adam.Parmenter@hdrinc.com](mailto:Adam.Parmenter@hdrinc.com)

612-501-2010

HDR