

96

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR
TO GOVERNMENT OF KERALA

No.B1-12522/2007/CEI.

Thiruvananthapuram
Dated : 17/07/2007

CIRCULAR

- Subject - Additional guide lines for issuing scheme approval and sanction for energization for electrical installations - modification - reg.
- Reference
1. Suggestions from the Kerala State 'A' Grade Electrical Contractors' Association vide letter No.KSAGECA/2006 dated 21.8.2006
 2. Decisions taken at the conference of Electrical Inspectors' on 11.12.2006
 3. Decisions taken at the Technical Expert Committee Meeting on 19.1.2007
 4. Circular No. B1-21363/2005/CEI dated 16/03/2007

The following modifications are made to the Sl. Nos-11 & 20 in the circular cited (4) above with immediate effect.

- 1) Sl. No. 11 of the circular is replaced with the following- "If annual maintenance contract is given to a licensed 'A' grade Electrical Contractor, Degree/Diploma holders in Electrical Engineering may not be insisted as authorized person in the case of high-rise residential/commercial buildings availing supply at 11kV, provided the aggregate transformer capacity doesn't exceed 500kVA."
- 2) Sl. No. 20 of the circular is replaced with the following- "When dry type transformers are installed above ground floor, 11kV A.B.S.F. Unit/Breaker has to be provided at ground floor for completely isolating the supply as envisaged in Rule 50(A) with lockable type push button near the transformers and a mechanical interlock in between the ABSF Unit/Breaker and the transformer enclosure."


Chief Electrical Inspector

To

1. The Deputy Chief Electrical Inspector, Ernakulam
2. All Electrical Inspectors *Kottayam*
3. All Technical officers of the Chief Electrical Inspector's office
4. B1, B3 & B4 Section
5. Stock File
6. 'A' Grade Electrical Contractors' Association.

Seen
9/8