



GOVERNMENT OF KERALA
DEPARTMENT OF ELECTRICAL INSPECTORATE
OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

No.B3/22132/01/CEI

Date: 26th July 2001
Thiruvananthapuram

Circular

Subject : General guidelines for scrutiny and approval of schemes

It has come to the notice of the Chief Electrical Inspector that there are some deviations on certain points while dealing with scrutiny of schemes in District Offices. In order to achieve uniformity in practices in all District Offices, the following guidelines are issued.

1. For demand and collection of Scrutiny fee for schemes of additions / alterations in existing installations, the scrutiny fee need be demanded and collected only for additions / alterations subject to the minimum fee as per Rules. When there is standardisation scheme along with additions / alterations then Scrutiny fee for the standardising portion may also be collected
2. The Transformer capacity of HT and EHT installations shall be decided on the basis of Maximum Demand and not Connected Load.
3. In Circular no.B1/14113/2001/CEI dated 24/5/2001, list of certain products approved by the Chief Electrical Inspector was included. The intention of that Circular was to avoid spurious non-standard products dumping in the field. So in addition to the products mentioned in that Circular the products of standard manufacturers, having valid Test Certificates from BIS,ERDA,CPRI etc to prove the quality of their products, shall also be permitted.


Chief Electrical Inspector

To

The Deputy Chief Electrical Inspector, Ernakulam
All Electrical Inspectors