

Government of Kerala
Department of Electrical Inspectorate
Office of the Chief Electrical Inspector
Housing Board Buildings, Shanthi Nagar
Thiruvananthapuram 695 001
Phone: 0471 2331104 , 0471 2331159
Email : cei@ceikerala.gov.in
Web site : www. ceikerala.gov.in



An IS 15700 : 2005 Certified Department

No.B4.15044 / 2011 / CEI

Dated: Thiruvananthapuram, 19 / 08 / 2011

CIRCULAR

Subject: Revised Guidelines for installation of Diesel Generator Sets - Regarding
Reference: National Building Code 2005

The following revised guide lines are issued for installation of DG Sets. Modifying the circular issued on 18/08/2011.

The generating sets should not be allowed to be installed above ground floor or below first basement level of building. There shall be provision of separate direct escape and entry into these areas from outside in case of fire.

All officers should intimate this to all contractors / clients who have already been got scheme approval from our department to relocate the generator sets as above.

Chief Electrical Inspector

To

1. The Deputy Chief Electrical Inspector, Ernakulam.
2. All Electrical Inspectors.
3. All Technical officers in the Office of the Chief Electrical Inspector.
4. The President, 'A' Class Electrical Contractors' Association.
5. Circular file.
6. Spare.
7. Stock file.