



301 West First Street • P.O. Box 394
 Cle Elum, WA 98922 • Ph. (509) 674-9642

**Sun Country Maintenance Association
 Water System Report – August 1, 2016**

Meters were read on August 1, 2016. All meters were read electronically or manually.

Well Production:

Total well production for July was 1,933,900 gallons, down 369,400 gallons from June's 2,303,300 gallons. The use period was 26 days. This equates to 74,381 gallons per day pumped.

Leak Report: (These are meters that have run continuously for a 24 hour period at some time since the previous reading) There were eight leaks reported. It is assumed that these are all users who were irrigating continuously for a 24 hour period. Use by Lot 1-3-11 does seem excessively high again this month.

LEAK REPORT				
LOT #	NAME	ADDRESS	USE FOR PERIOD	ON REPORT LAST MONTH?
1-1-5	Kanemori, Ray & Charlotte	230 Pebble Beach	20,570	YES
1-1-12	Sytsma, Don & Carol	390 Pebble Beach	35,510	NO
1-1-28	Mebius, John & Nikki	750 Pebble Beach	16,590	NO
1-2-38	Lewis, Melvin	191 Pebble Beach	34,290	NO
1-3-11	Jang/Cho, Wonsik/Kyuong Sook	1100 St Andrews Drive	66,620	YES
3-0-36	Larson, Bonnie	820 Oakmont Drive	13,740	NO
3-0-66	McHaffie, John & Susan	71 Pecon Valley Pl.	18,440	NO
3-0-98	Bergeron, Robert & Jimmie	781 Oakmont Drive	21,170	YES

Residential Usage Report:

Total residential metered use was 1,658,890 gallons, down from last month's 1,936,300 gallons. This is a decrease of 277,410 gallons. The use period was only 26 days compared to last month's 34.

Clubhouse Usage Report:

The clubhouse use was 87,400 gallons.

Total Usage and Unaccounted For Water:

Total well production was 1,933,900 gallons. All metered use was 1,746,290 gallons. Water use by the CL₂ tester plus system flushing was estimated at 60,000 gallons. This means the system had total estimated usage of 1,806,290 gallons of water. The estimated "unaccounted for" water (system leakage) was 127,610 gallons. This equates to 3.41 gallons per minute