

NAVAJO COUNTY FAIR FIRE INSPECTION VENDOR'S CHECKLIST

1. The vendor will be present at the location at the time of inspection.
2. Commercial hoods and extinguishers will be inspected before the event to ensure they are in proper working order. Documentation will be provided at the time of inspection.
3. If propane tanks are used, they will comply with NFPA 58. This includes having service records and tanks within the manufacturer's service dates. If propane tanks are off-gassing, the vendor will remove them from the site.
4. When generators are used, combustible liquids, such as gas tanks, will not be stored next to one another.
5. Per IFC code, an adequate power supply will be supplied. Larger appliances such as refrigerators and others will be plugged directly into outlets. Daisy chains and power strips are not approved to provide power for more significant amperage draws.
6. All compressed gas cylinders are to be secured.
7. A Class K extinguisher will be installed if cooking operations have grease vapors.
8. Open flame grills and cooking appliances will maintain proper distances from all combustible or flammable materials.
9. Parking or storage will not impede Designated Fire Lanes and Emergency Exits.
10. Vendors will be responsible for addressing violations that are cited at the time of inspection.

Thank you for your cooperation.

Danny Robinson
Deputy Fire Marshal
Office of State Fire Marshal
Department of Forestry and Fire Management
1110 W. Washington Street – Suite 500
Phoenix, AZ 85007
(480) 601-3355
drobinson@dffm.az.gov