




AGGREGATE GRADING ANALYSIS

Client: Smalldene Midlands Ltd

Sample Ref.	26.136
Source	Armoury Road, Small Heath
Material Description	75mm+
Date of Sample	26th May 2026
Date of Test	3rd June 2026
Sample Weight	3000

Sieve Size	Weight Retained	% Weight Retained	% Passing By Weight	Limits %	Pass/Fail
125mm	0.00	0.0%	100.0%	N/A	NA
90mm	214.00	7.1%	93.4%	N/A	N/A
75mm	2795.00	93.2%	9.7%	N/A	N/A
37.5mm	2975.00	99.2%	1.9%	N/A	N/A
20mm	3000.00	100.0%	0.0%	N/A	N/A
PAN	0.00	0.0%		N/A	N/A

Moisture %	1.70%
------------	-------



Signed

Dated

4th June 2026

8 Lincoln Court, London Road, Liphook, Hampshire GU30 7TB

Tel: 07700 169325

