

8 Lincoln Court, London Road, Liphook, Hampshire GU30 7TB

Tel: 0330 043 0523 Email: albert@albertcoleconsultants.co.uk


AGGREGATE GRADING ANALYSIS

Client Smalldene Midlands Ltd

Sample Ref.	24.435
Source	Armoury Road, Small Heath
Material Description	4-10mm
Date of Sample	3rd December 2024
Date of Test	12th December 2024
Sample Weight	750

Sieve Size	Cum. Weight Retained	% Weight Retained	% Passing By Weight	Limits %	Pass/Fail
20.0mm	0.00	0.0%	100.0%	100	PASS
14.0mm	15.00	2.0%	98.0%	98-100	PASS
10.0mm	87.00	11.6%	88.4%	85-99	PASS
4.0mm	712.00	94.9%	5.1%	0-20	PASS
2.0mm	732.00	97.6%	2.4%	0-5	PASS
PAN	750.00	100.0%			

Moisture % 4



The material tested complies with BS EN 12620 grading requirements

Signed



Dated

12th December 2024