



**Albert Cole
Consultants**
CONCRETE & SOILS CONSULTANCY

8 Lincoln Court, London Road, Liphook, Hampshire GU30 7TB

Tel: 07700 169325 Email: albert@albertcoleconsultants.co.uk


AGGREGATE GRADING ANALYSIS

Client: Smalldene Midlands

Sample Ref.	26.132
Source	Armoury Road, Small Heath
Material Description	Type 1
Date Sample Received	26th May 2026
Date of Test	3rd June 2026
Sample Weight (g)	3000

Sieve Size	Cum. Weight Retained	% Weight Retained	% Passing By Weight	Limits %	Pass/Fail
63mm	0.00	0.0%	100.0%	100	PASS
31.5mm	40.00	1.3%	98.7%	75-99	PASS
16mm	795.00	26.5%	73.5%	43-81	PASS
8mm	1132.00	37.7%	62.3%	23-66	PASS
4mm	1975.00	65.8%	34.2%	12-53	PASS
2mm	2279.00	76.0%	24.0%	6-42	PASS
1mm	2683.00	89.4%	10.6%	3-32	PASS
0.063mm	2896.00	96.5%	3.5%	0-9	PASS

Moisture %	6.50%
------------	-------



The material tested complies with the Specification for Highway Works Clause 803 for Type 1 Specification

[illegible]

