

8 Lincoln Court, London Road, Liphook, Hampshire GU30 7TB

Tel: 0330 043 0523 Email: albert@albertcoleconsultants.co.uk


AGGREGATE GRADING ANALYSIS

Client Smalldene Midlands Ltd

Sample Ref.	26.133
Source	Armoury Road, Small Heath
Material Description	4-10mm
Date of Sample	26th May 2026
Date of Test	3rd June 2026
Sample Weight	750

Sieve Size	Cum. Weight Retained	% Weight Retained	% Passing By Weight	Limits %	Pass/Fail
20.0mm	0.00	0.0%	100.0%	100	PASS
14.0mm	4.00	0.5%	99.5%	98-100	PASS
10.0mm	87.00	11.6%	88.4%	85-99	PASS
4.0mm	663.00	88.4%	11.6%	0-20	PASS
2.0mm	725.00	96.7%	3.3%	0-5	PASS
PAN	750.00	100.0%			

Moisture % 3.9



The material tested complies with BS EN 12620 grading requirements

Signed



Dated

4th June 2026

