

8 Lincoln Court, London Road, Liphook, Hampshire GU30 7TB

Tel: 0330 043 0523 Email: albert@albertcoleconsultants.co.uk


AGGREGATE GRADING ANALYSIS

Client Smalldene Midlands

Sample Ref.	24.436
Source	Armoury Road, Small Heath
Material Description	10-20mm
Date of Sample	3rd December 2024
Date of Test	12th December 2024
Sample Weight	1000

Sieve Size	Cum. Weight Retained	% Weight Retained	% Passing By Weight	Limits %	Pass/Fail
40.0mm	0.00	0.0%	100.0%	100	PASS
31.5mm	12.00	1.2%	98.8%	98-100	PASS
20.0mm	98.00	9.8%	90.2%	85-99	PASS
10.0mm	906.00	90.6%	9.4%	0-20	PASS
4.0mm	981.00	98.1%	1.9%	0-5	PASS
PAN	1000.00	100.0%			

Moisture %	3.8
------------	-----



The material tested complies with BS EN 12620 grading requirements

Signed



Dated

12th December 2024