



8 Lincoln Court, London Road, Liphook, Hampshire GU30 7TB

Tel: 07700 169325 Email: albert@albertcoleconsultants.co.uk


AGGREGATE GRADING ANALYSIS

Client: Smalldene Midlands

Sample Ref.	24.434
Source	Armoury Road, Small Heath
Material Description	Type 1
Date Sample Received	3rd December 2024
Date of Test	12th December 2024
Sample Weight (g)	3000

Sieve Size	Cum. Weight Retained	% Weight Retained	% Passing By Weight	Limits %	Pass/Fail
63mm	0.00	0.0%	100.0%	100	PASS
31.5mm	65.00	2.2%	97.8%	75-99	PASS
16mm	863.00	28.8%	71.2%	43-81	PASS
8mm	1270.00	42.3%	57.7%	23-66	PASS
4mm	2153.00	71.8%	28.2%	12-53	PASS
2mm	2403.00	80.1%	19.9%	6-42	PASS
1mm	2796.00	93.0%	7.0%	3-32	PASS
0.063mm	3000.00	100.0%	0.0%	0-9	PASS

Moisture %	9.80%
------------	-------



The material tested complies with the Specification for Highway Works Clause 803 for Type 1 Specification