


Particle Size Distribution Report



% + 3"	% GRAVEL	% SAND	% SILT	% CLAY	USCS	AASHTO	PL	LL
	0.5	89.5	10.0					

SIEVE inches size	PERCENT FINER		
	○		
3/8"	100.0		
GRAIN SIZE			
D ₆₀	1.06		
D ₃₀	0.329		
D ₁₀	0.0750		
COEFFICIENTS			
C _c	1.36		
C _u	14.17		

SIEVE number size	PERCENT FINER		
	○		
#4	99.5		
#10	79.6		
#30	43.7		
#40	36.2		
#50	27.7		
#100	14.4		
#200	10.0		

SOIL DESCRIPTION

○ Gray Well-Graded SAND w/ Silt

REMARKS:

○

○ Source: Sand

COOPER TESTING LABORATORY

Client: Casey Utility Services, Inc.

Project: Treasure Island

Project No.: 979-023

Figure