

300 4th Street
West Des Moines, IA 50265
515.724.7938

312 NW 10th Ave., Suite 100
Portland, OR 97209
503.212.4612

4014 N. Goldwater Blvd., Suite 203
Scottsdale, AZ 85251
480.666.0767

296 E. 5th Ave., Suite 501
Eugene, OR 97401
541.729.7645

CONSULTING ENGINEERS

Mechanical
Electrical
Plumbing
Lighting
Technology

Star School MakerSpace Building

Addendum #2

2022.09.06

This addendum is issued to modify, clarify or amend the original Project Drawings and Specifications and is hereby made part of the Contract Documents. The Contractor shall be responsible for incorporating items in this Addendum to the Work. The following shall take precedence over anything to the contrary in the Drawings or Specifications.

1. Clarification: E series sheets. Note that surface mounted conduit is allowed in all spaces to simplify installation.
2. Revision: Sheet E101, Detail #2, device shown as new “new well pump vfd” will instead be an existing relocated and reinstalled motor soft starter installed in adjacent building.
3. Revision: Sheet PD100, detail 1, existing grey water trench drain to remain.
4. Clarification: Sheet A011. Detail 01. Delete from scope the “Existing structure to be demolished” located at the N/W corner of the building. There is no existing structure outside this generator room.

End of Addendum #2