



ISO Checklist



1. Provide a list of Hose Test Records for each engine for the past three (3) years.
2. Provide Pump Test Records for each engine for the past three (3) years.
3. Provide the total number of training hours for each district firefighter for the past twelve (12) months in the following categories:
 - a. New Firefighter Training
 - b. New Driver/Operator Training
 - c. Officer Training
 - d. Facility Training
 - e. Company Training
 - f. Driver/Operator Training
 - g. Hazardous Materials Training
4. Provide documentation of annual hydrant inspections for the past three (3) years.
5. Provide an inventory of each engine and list any items which are not on your engine but required by (**ISO Form 500-2_F v020519**)
6. Provide copies of the last three (3) years of commercial building inspections along with their associated pre-fire plan.
7. Does your department have a minimum of two (2) functioning tankers with a capacity of at least 2000 gallons capacity a 2500 gallon drop tank, one (1) 10" dump and one (1) 3" tank fill?
8. Do you have at least four (4) SCBA packs and 4 spare cylinders on each engine?
9. Provide a list of all hydrant locations and flow rates.
10. Provide a list of fill times and dump times on tankers?
11. Record a video and time and time an evolution of setting up a pump to draft out of a drop tank.