

14 Chippewa Road, Sherwood Park, Alberta T8A 3Y1

Ph: (780) 467-0972 | Fx: (780) 416-6913

Email: info@aircheklab.ca Web: www.aircheklab.ca

Compressed Breathing Air Analysis

High Pressure (above 2216 psig)

Test Date: Job# 83405 July 23, 2025

Sample Collection Date: July 22, 2025 Sample Received: July 23, 2025

Submitted By: **Majestic Hydrotest & Fire**

Compressor: **Irwin Air** Serial #: 6971 Unit #: M13-3EVUS-CO

Cylinder # **HPFT 24** Hours: 2

Sampling Location: off of compressor

Compounds Present	Maximum Allowable CSA Z180.1	Measured Quantity		
ACM02				
Oxygen	20% - 22%		20.7	%
ACM05				
Nitrogen & Rare Gases	78% - 80%		79.3	%
Carbon Monoxide	5 ppm	<	0.75	ppm
Carbon Dioxide	600 ppm		398.6	ppm
Methane	10 ppm		2.1	ppm
Volatile Non-Methane Hydrocarbons	5 ppm	<	0.44	ppm
Volatile Halogenated Hydrocarbons	5 ppm	<	0.2	ppm
ACM04				
Odour	Free of Pronounced Odour	None		
ACM03				
Oil, Particulates & Condensates	1 mg / m3	<	0.1	mg / m3
ACM01				
Sample Dew Point	Minus 53 degrees C/27ppm	-63.9	°C	6.1 ppm

Sample Passed

The dewpoint, as measured in the above sample, limits the use of the compressed air to the pressure dew point temperature defined in Table 1 (Z180.1-19). The MEASURED quantities are otherwise WITHIN ... the limits of the standard Z180.1.

Compressed breathing air in cylinders and piping operating at pressures equal to or greater than 2216 psig

a) shall have an ATMOSPHERIC DEW POINT equal to or below -53 °C (27 ppm)

with CSA Standard

b) should have a PRESSURE DEW POINT 5°C below the lowest temperature to which the cylinder and piping may be exposed at any season of the year.

Results apply to sample as received. Data provided during sample collection is used in the calculation of ACM03. Analysis was conducted under controlled enviromental conditions.

This report may not be reproduced, except in full, without written consent from AirChekLab.

Suggested next testing date in accordance

January 23, 2026

A. Reay

118806.9 R.1.2

Entered by:

Analyst:

Val: 12-2