



SILVER TRADING
TIMBER FLOORING PTY LTD

ACOUSTIC CERTIFICATE

Date: Wednesday, 1st April 2015

To: Strata Management / Body Corporate

Floating Timber Floor Samples—Impact Noise Testing for Ceiling/Floor

Test By: **Koikas Acoustics Pty Ltd**

Reference: 1886C20120709mfSilverTradingTimberFlooring.docx

Tested to: **ISO 140.7:2006** and **ISO 717.2-2004**

Test Results

| System Tested | L'nw+Ci | BCA Criterion | Compliance Achieved? |
|--|---------|------------------|-------------------------|
| 8mm thick laminated timber + green underlay | 45 | L'nw+Ci≤62 | Y |
| 12mm thick laminated timber + green underlay | 46 | | Y |

Notes:

- BCA requirements are for a L'nw + Ci rating of 62 or Less.