



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Report Number: 17-06-03568

Received Date: 06/26/2017
Reported Date: 07/03/2017
Sampled By: Rita Vilorio
Tech Certification #:

Project/Test Address: 170640; Multiple Schools; Maplewood, NJ 07040

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narr
17-06-03568-001	2-MM-S	6/22/2017	TEACHER LOUNGE	<1.00	06/30/2017	✓
17-06-03568-002	9-MM-DW	6/22/2017	GIRLS LOCKER ROOM	3.00	06/30/2017	✓
17-06-03568-003	16-MM-FP	6/22/2017	KITCHEN	13.2	06/30/2017	✓
17-06-03568-004	15-TE-DW	6/22/2017	ROOM 122	27.9	06/29/2017	✓
17-06-03568-005	7-CS-S	6/22/2017	CONCESSION STAND	2.22	06/30/2017	✓
17-06-03568-006	8-MW-S	6/22/2017	GYM	<1.00	06/30/2017	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 17-06-03568

Project/Test Address: 170640; Multiple Schools; Maplewood, NJ 07040

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narr
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	------

Method: SM 3113B-2010

Accreditation #: NJ VA008

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water
 Analysis Report

Report Number: 17-06-03573

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Received Date: 06/26/2017
 Reported Date: 07/03/2017
 Sampled By: Rita Vilorio
 Tech Certification #:

Project/Test Address: 170640; Multiple Schools; South Orange, NJ 07079

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative
17-06-03573-001	2-SOM-WC	06/22/2017	ROOM 105 HALL	<1.00	06/30/2017	✓
17-06-03573-002	11-SOM-S	06/22/2017	NURSE OFFICE	2.73	06/30/2017	✓
17-06-03573-003	16-SOM-WC	06/22/2017	HALL BY JC 24	<1.00	06/30/2017	✓
17-06-03573-004	8-SMA-WC	06/22/2017	ROOM 103 HALL	<1.00	06/30/2017	✓
17-06-03573-005	11-SMA-DW	06/22/2017	ROOM 103	2.55	06/30/2017	✓
17-06-03573-006	1-SME-S	06/22/2017	ROOM 3	18.9	06/30/2017	✓
17-06-03573-007	2-SO-S	06/22/2017	GYM	<1.00	06/30/2017	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 17-06-03573

Project/Test Address: 170640; Multiple Schools; South Orange, NJ 07079

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narr
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	------

Method: SM 3113B-2010

Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion