



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY

USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: CATHERINE WINN
247 S BALDWIN RESORT RD
EAST TAWAS MI 48730

Sample ID: LJ70592

Work Order: 10800669_01

System Name/Owner:	HSRUA	WSSN/Pool ID:	03319
Collection Address:	247 S BALDWIN RESORT RD,EAST TA	Source:	TYPE I
Collected By:	MATT IZZO	Site Code:	TP001
Township/Well#/Section:	//	Collector:	Other
County:	Iosco	Date Collected:	08/04/2021 10:05
Sample Point:	TREATED WATER SAMPLE TAP	Date Received:	08/05/2021 11:34
Water System:	Public System Surface Water	Purpose:	Routine Monitoring

Sample Comment LJ70592 Results for PFAS are suspect. Recovery for the surrogate d5-NEtFOSAA is outside method required quality control acceptance limits due to a possible matrix interference. Sample was reanalyzed and reported per method requirements.

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	08/07/2021		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	08/07/2021		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	08/07/2021	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	08/07/2021	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	335-76-2
PFDaA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	08/07/2021	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	08/07/2021	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	08/07/2021	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	08/07/2021	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	08/07/2021	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	376-06-7
PFTrDA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	08/07/2021		EPA 537.1	2058-94-8

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample ID: LJ70592

Work Order: 10800669_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

District Health Dept. #2
420 West Lake St.
Tawas City, MI 48764
989 362-6183

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane